

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent improvement to left bank and right bank water course and nallah of Arla tank in V.P. Qurerim in Priol Constituency Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1982						164.44		No. WRD/WD XI/ SD IV/ W.F.CF/139/2020-21. <b>DATED: 17-02-2021</b>
	1983	25-01-2021	22-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	1984						164.44		
2	1985						164.44		
	1986	25-01-2021	22-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	161.48	do
	1987						160.00		
3	1988						164.44		
	1989	25-01-2021	22-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	162.96	do
	1990						164.44		
4	1991						164.44		
	1992	25-01-2021	22-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	161.48	do
	1993						160.00		
5	1994						160.00		
	1995	27-01-2021	24-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	160.00	do
	1996						160.00		
6	1997						160.00		
	1998	27-01-2021	24-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	161.48	do
	1999						164.44		
7	2000						160.00		
	2001	27-01-2021	24-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	160.00	do
	2002						160.00		
8	2003						160.00		
	2004	27-01-2021	24-02-2021	Foundation	1.2.4	150 kg/cm2	160.00	161.48	do
	2005						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent improvement to left bank and right bank water course and nallah of Arla tank in V.P. Qurerim in Priol Constituency Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
9	2006						168.89		No. WRD/WD XI/ SD IV/ W.F.CF/139/2020-21. <b>DATED: 17-02-2021</b>
	2007	29-01-2021	26-02-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	
	2008						168.89		
10	2009						168.89		do
	2010	29-01-2021	26-02-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	2011						168.89		
11	2012						168.89		do
	2013	29-01-2021	26-02-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	164.44	167.41	
	2014						168.89		
12	2015						168.89		do
	2016	29-01-2021	26-02-2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	2017						168.89		
13	2018						168.89		do
	2019	1/2/2021	1/3/2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	2020						164.44		
14	2021						168.89		do
	2022	1/2/2021	1/3/2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	2023						168.89		
15	2024						168.89		do
	2025	1/2/2021	1/3/2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	167.41	
	2026						164.44		
16	2027						168.89		do
	2028	1/2/2021	1/3/2021	Foundation	1.2.4	150 kg/cm <sup>2</sup>	168.89	168.89	
	2029						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**