

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the land bearing Chalta No. 221 of P.T. Sheet No. 3 of Margao City at Aquem, Margao.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1790						106.67		No. W.F. 260/SDIII /WD III WRD/ 2020-21/367. <b>DATED: 09-02-2021.</b>
	1791	4/2/2021	11/2/2021	In Foundation	1.2.4	100 kg/cm2	111.17	109.67	
	1792						111.17		
2	1793						106.67		do
	1794	4/2/2021	11/2/2021	In Foundation	1.2.4	100 kg/cm2	106.67	108.17	
	1795						111.17		
3	1796						111.17		do
	1797	6/2/2021	13-02-2021	In 1st Lift 0.00 m to 28.00 mts	1.2.4	100 kg/cm2	106.67	109.67	
	1798						111.17		
4	1799						106.67		do
	1800	6/2/2021	13-02-2021	In 1st Lift 0.00 m to 28.00 mts	1.2.4	100 kg/cm2	111.17	108.17	
	1801						106.67		
5	1802						115.56		do
	1803	8/2/2021	15-02-2021	In 2nd Lift 0.00 to 28.00 mts	1.2.4	100 kg/cm2	111.17	112.63	
	1804						111.17		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**