

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** ReConstruction of retaining wall of nallah at Rawanfond near Careiro Residential building in V.P. Aquem Baixo, Salcete- Goa.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	1						160.00		No. WRD/SD I/WD II/ F.Estt/667/2020-21. <b>DATED: 20-11-2020</b>
	2	13-11-2020	11/12/2020	Foundation	1.2.4	150 kg/cm2	168.89	164.44	
	3						164.44		
1.2	4						164.44		do
	5	13-11-2020	11/12/2020	Foundation	1.2.4	150 kg/cm2	164.44	162.96	
	6						160.00		
2.1	7						168.89		do
	8	14-11-2020	12/12/2020	Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	9						168.89		
2.2	10						164.44		do
	11	14-11-2020	12/12/2020	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	12						168.89		
3.1	13						177.78		do
	14	16-11-2020	14-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	173.33	176.30	
	15						177.78		
3.2	16						177.78		do
	17	16-11-2020	14-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	173.33	174.81	
	18						173.33		
4.1	19						164.44		do
	20	17-11-2020	15-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	160.00	162.96	
	21						164.44		
4.2	22						164.44		do
	23	17-11-2020	15-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	
	24						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** ReConstruction of retaining wall of nallah at Rawanfond near Careiro Residential building in V.P. Aquem Baixo, Salcete- Goa.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	25						160.00		No. WRD/SD I/WD II/ F.Estt/667/2020-21. <b>DATED: 20-11-2020</b>
	26	18-11-2020	16-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	168.89	164.44	
	27						164.44		
5.2	28						168.89		do
	29	18-11-2020	16-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	30						164.44		
6.1	31						160.00		do
	32	19-11-2020	17-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	164.44	164.44	
	33						168.89		
6.2	34						164.44		do
	35	19-11-2020	17-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	
	36						168.89		
7.1	38						164.44		No. WRD/SD I/WD II/ F.Estt/681/2020-21. <b>DATED: 01-12-2020</b>
	39	20-11-2020	18-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	40						168.89		
7.2	41						168.89		do
	42	20-11-2020	18-12-2020	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	43						164.44		
8.1	44						168.89		do
	45	21-11-2020	19-12-2020	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	46						168.89		
8.2	47						168.89		do
	48	21-11-2020	19-12-2020	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	49						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** ReConstruction of retaining wall of nallah at Rawanfond near Careiro Residential building in V.P. Aquem Baixo, Salcete- Goa.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	50						168.89		No. WRD/SD I/WD II/ F.Estt/681/2020-21. <b>DATED: 01-12-2020</b>
	51	23-11-2020	21-12-2020	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	52						173.33		
9.2	53						164.44		do
	54	23-11-2020	21-12-2020	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	55						168.89		
10.1	56						164.44		do
	57	24-11-2020	22-12-2020	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	58						168.89		
10.2	59						168.89		do
	60	24-11-2020	22-12-2020	Wall	1.2.4	150 kg/cm2	168.89	167.41	
	61						164.44		
11.1	62						173.33		do
	63	25-11-2020	23-12-2020	Wall	1.2.4	150 kg/cm2	164.44	168.89	
	64						168.89		
11.2	65						173.33		do
	66	25-11-2020	23-12-2020	Wall	1.2.4	150 kg/cm2	173.33	173.33	
	67						173.33		
12.1	116						173.33		No. WRD/SD I/WD II/ F.Estt/680/2020-21. <b>DATED: 01-12-2020</b>
	117	26-11-2020	24-12-2020	Wall	1.2.4	150 kg/cm2	177.78	176.30	
	118						177.78		
12.2	119						177.78		do
	120	26-11-2020	24-12-2020	Wall	1.2.4	150 kg/cm2	182.22	179.26	
	121						177.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** ReConstruction of retaining wall of nallah at Rawanfond near Careiro Residential building in V.P. Aquem Baixo, Salcete- Goa.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	122						173.33		No. WRD/SD I/WD II/ F.Estt/680/2020-21. <b>DATED: 01-12-2020</b>
	123	27-11-2020	25-12-2020	Wall	1.2.4	150 kg/cm2	173.33	173.33	
	124						173.33		
13.2	125						173.33		
	126	27-11-2020	25-12-2020	Wall	1.2.4	150 kg/cm2	177.78	176.30	do
	127						177.78		
14.1	128						173.33		
	129	28-11-2020	26-12-2020	Wall	1.2.4	150 kg/cm2	173.33	171.85	do
	130						168.89		
14.2	131						173.33		
	132	28-11-2020	26-12-2020	Wall	1.2.4	150 kg/cm2	173.33	173.33	do
	133						173.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**