

GOVERNMENT OF GOA
WATER RESOURCES DEPARTMENT
S.D.III., Works Div. XI, QUALITY CONTROL LABORATORY
Gogol - Margao - Goa.

No. WRD / WD XI / SDIII / F.59/ W.F. 99/Oct/2021 / 2021-22/250

Dated: 24/02/2022

Name of the Work: Development of tanks (Latbai) at Madditolop in V.P. Loliem Polem in Canacona Taluka.

Sample Sent by :- Assistant Engineer, SD I, WD XI, WRD, Canacona- Goa.

Letter no:- No. WRD/ WD XI/ SD I/ F.188/253/2021-22.

Dated:- 10-02-2022

Received On: 10-02-2022

Date of Tesing: 12-02-2022

REPORT

Sr No.	Type of Sample	Tested for	Result	Permissible value	REMARKS
F.99/01/2022	Coarse Sand	FM Silt & Clay Grading	2.684 2.60% Zone- II	2.3 to 3.1 Upto 5% I to III Zone	
F.99/02/2022	Aggregate-20 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	To get the 20mm graded aggregate nominal size blend 20mm & 10 mm metal in 1:1 proportion.
F.99/03/2022	Aggregate- 10 mm	Grading		As per IS-383-1970 (Re-affirmed in 1990)	

Junior Engineer

Assistant Engineer

Copy submitted to

- 1) Assistant Engineer, SDI, WD XI, WRD, Canacona, Goa.
- 2) Executive Engineer, WD XI, WRD, Rawanfong -Goa.
- 3) Office File.