

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall for existing nallah from Regina house to Fatima house in ward no.3 in V.P. Verna of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Aquem Baixo, Rawanfond,Salcete Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1262						173.33		No. WRD/ SD I/WD II/ F.Esst/ 773 /2020-21. <b>DATED: 14-01-2021</b>
	1263	28-12-2020	25-01-2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	1264						168.89		
2	1265						168.89		do
	1266	30-12-2020	27-01-2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	1267						173.33		
3	1268						173.33		do
	1269	2/1/2021	30-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	1270						168.89		
4	1271						173.33		do
	1272	2/1/2021	30-01-2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	1273						173.33		
5	1274						168.89		do
	1275	4/1/2021	1/2/2020	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	1276						173.33		
6	1277						173.33		do
	1278	4/1/2021	1/2/2020	Wall	1.2.4	150 kg/cm2	173.33	171.85	
	1279						168.89		
7	1280						168.89		do
	1281	6/1/2021	3/2/2021	Wall	1.2.4	150 kg/cm2	168.89	170.37	
	1282						173.33		
8	1283						173.33		do
	1284	6/1/2021	3/2/2021	Wall	1.2.4	150 kg/cm2	173.33	171.85	
	1285						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall for existing nallah from Regina house to Fatima house in ward no.3 in V.P. Verna of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Aquem Baixo, Rawanfond,Salcete Goa.

NAME OF THE AGENCY					TESTING PERIOD				
					28 days.				
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	1286						168.89		No. WRD/ SD I/WD II/
	1287	6/1/2021	3/2/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	168.89	170.37	F.Esst/ 773 /2020-21.
	1288						173.33		<b>DATED: 14-01-2021</b>
2	1289						173.33		
	1290	9/1/2021	6/2/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	173.33	171.85	do
	1291						168.89		
3	1292						168.89		
	1293	9/1/2021	6/2/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	168.89	170.37	do
	1294						173.33		
4	1295						173.33		
	1296	11/1/2021	8/2/2021	Wall	1.2.4	150 kg/cm <sup>2</sup>	173.33	171.85	do
	1297						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**