

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent protection to nallah bank side in Sy.No. 83 at Daab Karsange in V.P. Borim Shiroda Constituency Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	8867						115.56		No. WRD/WD XI/ SD IV/ W.F.cf/297/2021-22. <b>DATED: 28-08-2021</b>
	8868	24-08-2021	31-08-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	8869						120.00		
2	8870						115.56		
	8871	25-08-2021	1/9/2021	Foundation	1.2.4	100 kg/cm2	120.00	115.56	do
	8872						111.11		
3	8873						115.56		
	8874	26-08-2021	2/9/2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	do
	8875						111.11		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**