

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of open type bandhara at Khutiya Padi in V.P. Barcem- Quedem in Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2810						191.11		No. WRD/WD XII/ SD V/ F.15/ 199/2020-21. DATED: 10-03-2021
	2811	5/3/2021	12/3/2021	Pier Foundation	1.1.5.3	175 kg/cm2	182.22	186.66	
	2812						186.66		
2	2813						182.22		
	2814	6/3/2021	13-03-2021	Pier	1.1.5.3	175 kg/cm2	186.66	183.70	do
	2815						182.22		
3	2816						182.22		
	2817	8/3/2021	15-03-2021	Pier	1.1.5.3	175 kg/cm2	182.22	182.22	do
	2818						182.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of open type bandhara at Khutiya Padi in V.P. Barcem- Quedem in Quepem Taluka.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2819						271.11		No. WRD/WD XII/ SD V/
	2820	5/3/2021	2/4/2021	Pier Foundation	1.1.5.3	265 kg/cm2	275.55	277.03	F.15/ 199/2020-21.
	2821						284.44		DATED: 10-03-2021
2	2822						280.00		
	2823	6/3/2021	3/4/2021	Pier	1.1.5.3	265 kg/cm2	271.11	275.55	do
	2824						275.55		
3	2825						271.11		
	2826	8/3/2021	5/4/2021	Pier	1.1.5.3	265 kg/cm2	275.55	277.03	do
	2827						284.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER