

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Lining of M I Tank at Chapoli in Canacona Taluka.

SAMPLE SENT BY: AE, SD II, WD XI, WRD, Canacona- Goa.

NAME OF THE AGENCY				TESTING PERIOD			28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTI ON	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	118						280.00		No.WRD/SD II/ WD XI/ F.81/211/2019-20. Dated:- 13-11-2019
1	119	18-10-2019	15-11-2019	CH 150.00 to 273.00	1.2.4	210 kg/cm2	288.88	284.44	
	120						293.33		
	121						288.88		
2	122	18-10-2019	15-11-2019	CH 150.00 to 273.00	1.2.4	210 kg/cm2	284.44	288.88	do
	123						288.88		
	124						293.33		
3	125	19-10-2019	16-11-2019	CH 273.00 to 391.00	1.2.4	210 kg/cm2	288.88	291.85	do
	126						293.33		
	127						284.44		
4	128	19-10-2019	16-11-2019	CH 273.00 to 391.00	1.2.4	210 kg/cm2	288.88	288.88	do
	129						293.33		
	130						288.88		
5	131	20-10-2019	17-11-2019	CH 391.00 to 520.00	1.2.4	210 kg/cm2	293.33	290.36	do
	132						288.88		
	133						288.88		
6	134	20-10-2019	17-11-2019	CH 391.00 to 520.00	1.2.4	210 kg/cm2	293.33	287.40	do
	135						280.00		
	136						280.00		
7	137	24-10-2019	21-11-2019	CH 520.00 to 720.00	1.2.4	210 kg/cm2	288.88	285.92	do
	138						288.88		
	139						293.33		
8	140	24-10-2019	21-11-2019	CH 520.00 to 720.00	1.2.4	210 kg/cm2	284.44	287.40	do
	141						284.44		

Joaquim Antao
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER