GOVERNMENT OF GOA OUALITY CONTROL LABORATORY WATER RESOURCES DFEPARTMENT

Test Report No.: WRD/Q.C. / F.75 /Aggr-T- 193,194/Lab/175/2022-23 Dated: 19/10/2022.

Laboratory: Bicholim-Goa

Sand –T: 5308, Cement-T: 1380

Sub Div: V (OC)/W.D.VIII/Bicholim Goa.

Sub: Urgent Repair for Bastora Minor -2 (Extensions) and OR-1 of Calangute Distributory of Left Bank Main Canal in Guirim Village of Bardez Taluka.

Ref to requisition No:- SDI/WDVIII/WRD/WF.75/2022-23/137

Dated: 13/10/2022.

Otv. Received: 1 bags each

Date of Receipt: 14/10/2022 **Tested on:** 15,17 & 18/10/2022. **Ref to Specification:** CPWD 2009, Vol. I&IS: 4031-4-1968

Sample: Sand, 20mm,

O.S. No. 9384/SS,9385/SS,830/RK,823/RK. Lab. Sample No.: 5300 To 5303 Tested by: Mrs. S.B. Naik Shirodkar J.E. & Mrs. R.R Kadam A.E.

12.5mm size Aggr, Sand, and Cement

REPORT 01 OF 01

Sr. No.	Description of sample	Tested for	Results	Max. /Min. value permissible	Remark
1. 2.	20 mm Size Aggregate: 12.5 mm Size Aggregate:		It is single sized aggregate of It is not single sized aggregat	20 mm nominal size. (Qty. rep. 40m ³) e of 12.5 mm nominal size. (Qty. rep. 40 m ³))
				n aggregates at the ratio of $\underline{1:2}$ by weight; it regate of 20 mm nominal size.	is
3.	Coarse Sand: (L.S.No.5302)	i) Silt & Clay by S.A. methodii) Silt by sedimentation	: - 5.80 % : - 5.55 %		
		iii) Fineness Modulus	: - 2.26 %		

Cement: JK Cement, bearing IS:269 Ordinary Portland cement,

i) Fineness of Cement : 1.03 % ----- (It should not be more than 10%) ii) Consistency of cement

: 31.50 % (It should be in the neighborhood of 35%) : 160 minutes ---- (It should not be less than 30 minutes)

Manuf. date: W:- 40, M:- 10, Y:- 2022 CM/L = 0003401034

iii) Initial Setting Time iv) Final Setting Time

: 310 minutes -- (It should not be more than 600 minutes)

Qty. rep. – <u>--</u>.

To be used for concrete work 1:2:4 - REMARK: The observed results are within the permissible limit for Ordinary Portland cement.

Copy to: 1. The Assistant Engineer, SD I, WD VIII, W.R.D. Karaswada Bardez-Goa.

- 2. Copy Submitted to The Superintending Engineer, CPO, WRD, Sinchai Bhavan Porvorim-Goa for kind Information
- 3. Copy Submitted to The Executive Engineer, WD. VIII, W.R.D, Karaswada Bardez-Goa
- 4. O.C. Lab file 5. Bill File.