GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DFEPARTMENT

Test Report No.: WRD/Q.C. / F.6-4 /Aggr-T- 209,210/Lab/202/2022-23 Dated: 12/12/2022 <u>Laboratory</u>: Bicholim-Goa

Sand -T: 5318, Cement-T: 1388

Sub Div: V (QC)/W.D.VIII/Bicholim Goa.

<u>Sub</u>: Improvement to existing compound wall behind TIP Rest House at Tillari Irrigation Project Complex at Karaswada Bardez Goa.

Ref to requisition No:- SDIII/WDVIII/WRD/WF.105/2022-23/188

Dated: 25/11/2022.

Oty. Received: 1 bags each

Date of Receipt: 02/12/2022 **Tested on**: 05 & 06/12/2022. **Ref to Specification:** CPWD 2009, Vol. I&IS: 4031-4-1968

Sample: 20mm,

O.S. No: 9512,9513,9516,9510/SS. Lab. Sample No: 5436 To 5439

Tested by: Mrs. S.B. Naik Shirodkar J.E.

12.5mm size Aggr, Sand, and Cement

REPORT 01 OF 01

Sr. No.	Description of sample	Tested for	Results	Max. /Min. value permissible	Remark
1. 2.	20 mm Size Aggregate: 12.5 mm Size Aggregate:	Particle size distribution: Particle size distribution:		ate of 20 mm nominal size. (Qty. rep	
<u>REMARK</u> : After blending 20 mm aggregate with 12.5 mm aggregates at the ratio of <u>1:1</u> by weight; it is Satisfying the required criteria for graded aggregate of 20 mm nominal size.					
3.	Coarse Sand: (L.S.No.5438)	i) Silt & Clay by S.A. method ii) Silt by sedimentation iii) Fineness Modulus iv) Grading Zone	: - 4.80 % : - 4.34 % : - 2.56 % : - II		
REMARK : The observed results are within the permissible limits of the Coarse sand.					
4.	Cement: JK Cement, bearing IS:269 Ordinary Portland cement, Manuf. date:W:- 47, M:- 10, CM/L = 0003401033 Qty. rep	i) Fineness of C ii) Consistency of iii) Initial Setting Y:- 2022 iv) Final Setting	f cement : 32.00 % (I g Time : 145 minutes	t should be in the neighborhood of 35%) (It should not be less than 30 minutes) (It should not be more than 600 minutes)	
To be used for 1:2:4 mix – REMARK: The observed results are within the permissible limit for Ordinary Portland cement.					

Copy to: 1. The Assistant Engineer, SD III, WD VIII, W.R.D. Karaswada, Bardez-Goa.

- 2. Copy Submitted to The Superintending Engineer, CPO, WRD, Sinchai Bhavan Porvorim-Goa for kind Information
- 3. Copy Submitted to The Executive Engineer, WD. VIII, W.R.D, Karaswada, Bardez-Goa.
- 4. Q.C. Lab file 5. Bill File.