

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	8474						168.89		No. SD I/ WD I/ WRD/ F.57/2021-22/122 DATED: 29-06-2021
	8475	4/6/2021	2/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	173.33	171.85	
	8476						173.33		
1.2	8477						173.33		do
	8478	4/6/2021	2/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	173.33	173.33	
	8479						173.33		
2.1	8480						173.33		do
	8481	5/6/2021	3/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	168.89	171.85	
	8482						173.33		
2.2	8483						173.33		do
	8484	5/6/2021	3/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	168.89	170.37	
	8485						168.89		
3.1	8486						160.00		do
	8487	7/6/2021	5/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	162.96	
	8488						164.44		
3.2	8489						164.44		do
	8490	7/6/2021	5/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	164.44	
	8491						164.44		
4.1	8492						164.44		do
	8493	8/6/2021	6/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	164.44	165.92	
	8494						168.89		
4.2	8495						164.44		do
	8496	8/6/2021	6/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	160.00	162.96	
	8497						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	8498						164.44		No. SD I/ WD I/ WRD/ F.57/2021-22/122 DATED: 29-06-2021
	8499	9/6/2021	7/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	164.44	165.92	
	8500						168.89		
5.2	8501						164.44		do
	8502	9/6/2021	7/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	160.00	162.96	
	8503						164.44		
6.1	8504						164.44		do
	8505	10/6/2021	8/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	168.89	167.41	
	8506						168.89		
6.2	8507						168.89		do
	8508	10/6/2021	8/7/2021	Foundation & Plinth	1.2.4	150 kg/cm2	168.89	168.89	
	8509						168.89		
7.1	8510						164.44		do
	8511	11/6/2021	9/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	160.00	164.44	
	8512						168.89		
7.2	8513						164.44		do
	8514	11/6/2021	9/7/2021	1st and 2nd lift	1.2.4	150 kg/cm2	164.44	165.92	
	8515						168.89		
8.1	8516						164.44		do
	8517	12/6/2021	10/7/2021	2nd and 3rd Lift	1.2.4	150 kg/cm2	164.44	162.96	
	8518						160.00		
8.2	8519						164.44		do
	8520	12/6/2021	10/7/2021	2nd and 3rd Lift	1.2.4	150 kg/cm2	160.00	162.96	
	8521						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	8522						164.44		No. SD I/ WD I/ WRD/ F.57/2021-22/122 DATED: 29-06-2021
	8523	14-06-2021	12/7/2021	3rd Lift	1.2.4	150 kg/cm2	164.44	162.96	
	8524						160.00		
9.2	8525						164.44		
	8526	14-06-2021	12/7/2021	3rd Lift	1.2.4	150 kg/cm2	164.44	164.44	do
	8527						164.44		
10.1	8528						168.89		
	8529	15-06-2021	13-07-2021	2nd & 3 rd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	8530						164.44		
10.2	8531						164.44		
	8532	15-06-2021	13-07-2021	2nd & 3 rd Lift	1.2.4	150 kg/cm2	168.89	165.92	do
	8533						164.44		
11.1	8534						173.33		
	8535	16-06-2021	14-07-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	170.37	do
	8536						168.89		
11.2	8537						173.33		
	8538	16-06-2021	14-07-2021	3rd Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	8539						168.89		
12.1	8540						164.44		
	8541	17-06-2021	15-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	162.96	do
	8542						160.00		
12.2	8543						168.89		
	8544	17-06-2021	15-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	165.92	do
	8545						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
13.1	8546						168.89		No. SD I/ WD I/ WRD/ F.57/2021-22/122 DATED: 29-06-2021
	8547	18-06-2021	16-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	173.33	170.37	
	8548						168.89		
13.2	8549						168.89		
	8550	18-06-2021	16-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	168.89	168.89	do
	8551						168.89		
14.1	8552						164.44		
	8553	19-06-2021	17-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	168.89	167.41	do
	8554						168.89		
14.2	8555						168.89		
	8556	19-06-2021	17-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	168.89	168.89	do
	8557						168.89		
15.1	8558						164.44		
	8559	21-06-2021	19-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	160.00	164.44	do
	8560						168.89		
15.2	8561						164.44		
	8562	21-06-2021	19-07-2021	Foundation & Plinth	1.2.4	150 kg/cm ²	164.44	165.92	do
	8563						168.89		
16.1	8564						164.44		
	8565	22-06-2021	20-07-2021	3rd Lift	1.2.4	150 kg/cm ²	164.44	162.96	do
	8566						160.00		
16.2	8567						164.44		
	8568	22-06-2021	20-07-2021	3rd Lift	1.2.4	150 kg/cm ²	160.00	162.96	do
	8569						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17.1	8570						164.44		No. SD I/ WD I/ WRD/ F.57/2021-22/122 DATED: 29-06-2021
	8571	23-06-2021	21-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	162.96	
	8572						160.00		
17.2	8573						164.44		
	8574	23-06-2021	21-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	164.44	do
	8575						164.44		
18.1	8576						168.89		
	8577	24-06-2021	22-07-2021	1st and 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	8578						164.44		
18.2	8579						164.44		
	8580	24-06-2021	22-07-2021	1st and 2nd Lift	1.2.4	150 kg/cm2	168.89	165.92	do
	8581						164.44		
19.1	8582						173.33		
	8583	25-06-2021	23-07-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	170.37	do
	8584						168.89		
19.2	8585						173.33		
	8586	25-06-2021	23-07-2021	3rd Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	8587						168.89		
20.1	8588						164.44		
	8589	26-06-2021	24-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	162.96	do
	8590						160.00		
20.2	8591						168.89		
	8592	26-06-2021	24-07-2021	Foundation & Plinth	1.2.4	150 kg/cm2	164.44	165.92	do
	8593						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall of nallah from Satish Pednekar house to Hari Tuyenkar house in Malbar bund V.P. Anjuna Caisua in Siolim Constituency.

SAMPLE SENT BY: AE, SD I, WD I, WRD, Porvorim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
21.1	8594						168.89		No. SD I/ WD I/ WRD/
	8595	27-06-2021	25-07-2021	2nd and 3rd Lift	1.2.4	150 kg/cm2	173.33	171.85	F.57/2021-22/122
	8596						173.33		DATED: 29-06-2021
21.2	8597						173.33		
	8598	27-06-2021	25-07-2021	2nd and 3rd Lift	1.2.4	150 kg/cm2	173.33	173.33	do
	8599						173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER