

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall for hillock adjoining Chalta No. 220 of P.T. Sheet No. 3 at Aquem of Margao City.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1052						106.67		No. W.F.259/SD III/WD III/ WRD/2020-21/332 DATED: 13-01-2021
	1053	8/1/2021	15-01-2021	In Foundation	1.2.4	100 kg/cm2	111.11	111.11	
	1054						115.56		
2	1055						111.11		do
	1056	12/1/2021	19-01-2021	In 1st Lift 0.00m to 10.20 m	1.2.4	100 kg/cm2	111.11	112.59	
	1057						115.56		
3	1478						115.56		No. W.F.259/SD III/WD III/ WRD/2020-21/347 DATED: 27-01-2021
	1479	21-01-2021	28-01-2021	In 2nd Lift 0.00 m to 10.20 m	1.2.4	100 kg/cm2	111.11	112.59	
	1480						111.11		
4	1481						106.67		do
	1482	22-01-2021	29-01-2021	In 1st Lift 10.20 m to 17.25 m	1.2.4	100 kg/cm2	115.56	111.11	
	1483						111.11		
5	1484						111.11		do
	1485	25-01-2021	1/2/2021	In 2nd Lift 10.20 m to 17.25 m	1.2.4	100 kg/cm2	111.11	112.59	
	1486						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER