

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement & Strengthening of pump foundation at Lift Irrigation Scheme Naikaband at Vaddem Rehabilitation Site.

SAMPLE SENT BY: AE, SD IV, WD X, WRD, Pajimol, Sanguem- Goa.

NAME OF THE AGENCY

TESTING PERIOD 28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.145/01/2021					385.09		No. WRD/WD X/SD IV/
	F.145/02/2021	15-06-2022	13-07-2022	Foundation	M 30	351.12	357.16	F.E.12/59/2022-23
	F.145/03/2021					335.26		DATED:- 08-07-2022.
2	F.145/04/2021					337.52		
	F.145/05/2021	16-06-2022	14-07-2022	Foundation	M 30	366.97	353.38	do
	F.145/06/2021					355.65		
3	F.145/07/2021					346.59		
	F.145/08/2021	17-06-2022	15-07-2022	Retaining Wall	M 30	355.65	354.89	do
	F.145/09/2021					362.44		
4	F.145/10/2021					382.83		
	F.145/11/2021	18-06-2022	16-07-2022	Platform	M 30	348.85	366.97	do
	F.145/12/2021					369.24		

JUNIOR ENGINEER.

ASSISTANT ENGINEER