

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	5633						253.33		No. WRD/ SD I/WD XII/ F.47/92/2021-22. <b>DATED: 04-08-2021.</b>
	5634	30-07-2021	27-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	257.78	254.81	
	5635						253.33		
7.2	5636						253.33		do
	5637	30-07-2021	27-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	253.33	253.33	
	5638						253.33		
8.1	5639						248.89		do
	5640	30-07-2021	27-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	253.33	250.37	
	5641						248.89		
8.2	5642						248.89		do
	5643	30-07-2021	27-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	253.33	251.85	
	5644						253.33		
9.1	5645						253.33		do
	5646	31-07-2021	28-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	253.33	253.33	
	5647						253.33		
9.2	5648						253.33		do
	5649	31-07-2021	28-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	257.78	254.81	
	5650						253.33		
10.1	5651						248.89		do
	5652	31-07-2021	28-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	248.89	250.37	
	5653						253.33		
10.2	5654						253.33		do
	5655	31-07-2021	28-08-2021	Raft foundation of pump house	1.1.5.3	200 kg/cm2	257.78	254.81	
	5656						253.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	5657						257.78		No. WRD/ SD I/WD XII/ F.47/92/2021-22. <b>DATED: 04-08-2021.</b>
	5658	3/8/2021	31-08-2021	Raft foundation (Beams)	1.1.5.3	200 kg/cm2	262.22	256.30	
	5659						248.89		
11.2	5660						257.78		do
	5661	3/8/2021	31-08-2021	Raft foundation (Beams)	1.1.5.3	200 kg/cm2	257.78	259.26	
	5662						262.22		
12.1	5689						257.78		No. WRD/ SD I/WD XII/ F.47/105/2021-22. <b>DATED: 24-08-2021.</b>
	5690	11/8/2021	8/9/2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	257.78	257.78	
	5691						257.78		
12.2	5692						257.78		do
	5693	11/8/2021	8/9/2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	257.78	259.26	
	5694						262.22		
13.1	5695						248.89		do
	5696	12/8/2021	9/9/2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	253.33	251.85	
	5697						253.33		
13.2	5698						253.33		do
	5699	12/8/2021	9/9/2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	253.33	253.33	
	5700						253.33		
14.1	5701						248.89		do
	5702	23-08-2021	20-09-2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	253.33	251.85	
	5703						253.33		
14.2	5704						253.33		do
	5705	23-08-2021	20-09-2021	Retaining wall of pump house	1.1.5.3	200 kg/cm2	253.33	253.33	
	5706						253.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.1	5707						248.89		No. WRD/ SD I/WD XII/ F.47/105/2021-22. <b>DATED: 24-08-2021.</b>
	5708	23-08-2021	20-09-2021	Coloumn of Pump house	1.1.5.3	200 kg/cm2	253.33	251.85	
	5709						253.33		
15.2	5710						253.33		do
	5711	23-08-2021	20-09-2021	Coloumn of Pump house	1.1.5.3	200 kg/cm2	253.33	253.33	
	5712						253.33		
16.1	5745						168.89		No. WRD/ SD I/WD XII/ F.47/118/2021-22. <b>DATED: 08-09-2021</b>
	5746	30-08-2021	27-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	173.33	171.85	
	5747						173.33		
16.2	5748						173.33		do
	5749	30-08-2021	27-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	173.33	173.33	
	5750						173.33		
17.1	5751						177.78		do
	5752	30-08-2021	27-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	177.78	176.30	
	5753						173.33		
17.2	5754						177.78		do
	5755	30-08-2021	27-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	168.89	173.33	
	5756						173.33		
18.1	5757						168.89		do
	5758	1/9/2021	29-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	173.33	171.85	
	5759						173.33		
18.2	5760						173.33		do
	5761	1/9/2021	29-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	173.33	173.33	
	5762						173.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.1	5763						173.33		No. WRD/ SD I/WD XII/ F.47/118/2021-22. <b>DATED: 08-09-2021</b>
	5764	1/9/2021	29-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	173.33	173.33	
	5765						173.33		
19.2	5766						177.78		do
	5767	1/9/2021	29-09-2021	Delivery Tank RM 1	1.2.4	150 kg/cm2	177.78	176.30	
	5768						173.33		
20.1	6975						257.78		No. WRD/ SD I/WD XII/ F.47/123/2021-22. <b>DATED: 21-09-2021</b>
	6976	14-09-2021	12/10/2021	Pump house ground floor slab	1.1.5.3	200 kg/cm2	257.78	259.26	
	6977						262.22		
20.2	6978						248.89		do
	6979	14-09-2021	12/10/2021	Pump house ground floor slab	1.1.5.3	200 kg/cm2	253.33	251.85	
	6980						253.33		
21.1	6981						253.33		do
	6982	14-09-2021	12/10/2021	Pump house ground floor slab	1.1.5.3	200 kg/cm2	253.33	253.33	
	6983						253.33		
21.2	6984						248.89		do
	6985	14-09-2021	12/10/2021	Pump house ground floor slab	1.1.5.3	200 kg/cm2	253.33	251.85	
	6986						253.33		
22.1	9107						248.89		No. WRD/ SD I/WD XII/ F.47/142/2021-22. <b>DATED: 19-10-2021</b>
	9108	9/10/2021	6/11/2021	Pump house above ground	1.1.5.3	200 kg/cm2	257.78	253.33	
	9109			floor columns			253.33		
22.2	9110						253.33		do
	9111	9/10/2021	6/11/2021	Pump house above ground	1.1.5.3	200 kg/cm2	253.33	253.33	
	9112			floor columns			253.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
23	9113						413.33		No. WRD/ SD I/WD XII/ F.47/142/2021-22. <b>DATED: 19-10-2021</b>
	9114	12/10/2021	9/11/2021	Rising Main -I delivery Tank Raft	M30		431.11	423.70	
	9115						426.67		
24	9116						431.11		do
	9117	12/10/2021	9/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9118						431.11		
25	9119						426.67		do
	9120	12/10/2021	9/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9121						431.11		
26	9122						426.67		do
	9123	12/10/2021	9/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9124						431.11		
27	9125						431.11		do
	9126	13-10-2021	10/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9127						431.11		
28	9128						431.11		do
	9129	13-10-2021	10/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9130						431.11		
29	9131						431.11		do
	9132	13-10-2021	10/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9133						431.11		
30	9134						426.67		do
	9135	13-10-2021	10/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9136						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
31	9137						426.67		No. WRD/ SD I/WD XII/ F.47/142/2021-22. <b>DATED: 19-10-2021</b>
	9138	14-10-2021	11/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9139						431.11		
32	9140						426.67		do
	9141	14-10-2021	11/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9142						431.11		
33	9143						431.11		do
	9144	14-10-2021	11/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9145						431.11		
34	9146						431.11		do
	9147	14-10-2021	11/11/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9148						431.11		
35	9149						413.33		do
	9150	16-10-2021	13-11-2021	Rising Main -I delivery Tank Raft	M30		431.11	423.70	
	9151						426.67		
36	9152						431.11		do
	9153	16-10-2021	13-11-2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9154						431.11		
37	9155						426.67		do
	9156	16-10-2021	13-11-2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9157						431.11		
38	9158						431.11		do
	9159	16-10-2021	13-11-2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9160						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
39	9194						431.11		No. WRD/ SD I/WD XII/ F.47/154/2021-22. <b>DATED: 01-11-2021</b>
	9195	28-10-2021	25-11-2021	Rising Main -I delivery Tank	M30		426.67	429.63	
	9196			Wall (upto 0.90 m Height)			431.11		
40	9197						431.11		do
	9198	28-10-2021	25-11-2021	Rising Main -I delivery Tank	M30		426.67	429.63	
	9199			Wall (upto 0.90 m Height)			431.11		
41	9200						413.33		do
	9201	28-10-2021	25-11-2021	Rising Main -I delivery Tank	M30		431.11	423.70	
	9202			Wall (upto 0.90 m Height)			426.67		
42	9203						431.11		do
	9204	28-10-2021	25-11-2021	Rising Main -I delivery Tank	M30		426.67	429.63	
	9205			Wall (upto 0.90 m Height)			431.11		
43	9206						426.67		do
	9207	29-10-2021	26-11-2021	Rising Main -I delivery Tank	M30		426.67	428.15	
	9208			Baffle Wall (upto 0.90 m Height)			431.11		
44	9209						413.33		No. WRD/ SD I/WD XII/ F.47/163/2021-22. <b>DATED: 11-11-2021</b>
	9210	6/11/2021	4/12/2021	Rising Main -I delivery Tank Raft	M30		431.11	423.70	
	9211			Wall 2nd Lift			426.67		
45	9212						431.11		do
	9213	6/11/2021	4/12/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9214			Wall 2nd Lift			431.11		
46	9215						426.67		do
	9216	6/11/2021	4/12/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9217			Wall 2nd Lift			431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
47	9218						426.67		No. WRD/ SD I/WD XII/ F.47/163/2021-22. <b>DATED: 11-11-2021</b>
	9219	10/11/2021	8/12/2021	Rising Main -I delivery Tank Raft	M30		426.67	428.15	
	9220			Wall 3rd Lift			431.11		
48	9221						431.11		do
	9222	10/11/2021	8/12/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9223			Wall 3rd Lift			431.11		
49	9224						431.11		do
	9225	10/11/2021	8/12/2021	Rising Main -I delivery Tank Raft	M30		426.67	429.63	
	9226			Wall 3rd Lift			431.11		
50	9423						248.89		No. WRD/ SD I/WD XII/ F.47/293/2021-22. <b>DATED: 01-02-2022</b>
	9424	21-01-2022	18-02-2022	Thrust Block No.1	1.1.5.3	200 kg/cm2	253.33	251.85	
	9425						253.33		
51	9426						253.33		do
	9427	21-01-2022	18-02-2022	Thrust Block No.2	1.1.5.3	200 kg/cm2	253.33	253.33	
	9428						253.33		
52	9429						248.89		do
	9430	21-01-2022	18-02-2022	Thrust Block No.3	1.1.5.3	200 kg/cm2	253.33	251.85	
	9431						253.33		
53	9432						248.89		do
	9433	21-01-2022	18-02-2022	Thrust Block No.3	1.1.5.3	200 kg/cm2	257.78	253.33	
	9434						253.33		
54	9435						253.33		do
	9436	27-01-2022	24-02-2022	Thrust Block No.4	1.1.5.3	200 kg/cm2	253.33	253.33	
	9437						253.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**



**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
55	9438						253.33		No. WRD/ SD I/WD XII/ F.47/293/2021-22. <b>DATED: 01-02-2022</b>
	9439	27-01-2022	24-02-2022	Thrust Block No.5	1.1.5.3	200 kg/cm2	253.33	253.33	
	9440						253.33		
56	9441						248.89		do
	9442	28-01-2022	25-02-2022	Thrust Blocks No. 6	1.1.5.3	200 kg/cm2	253.33	251.85	
	9443			Wall 3rd Lift			253.33		
57.1	9529						431.11		No. WRD/ SD I/WD XII/ F.47/335/2021-22. <b>DATED: 21-03-2022</b>
	9530	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9531						431.11		
57.2	9532						431.11		do
	9533	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9534						431.11		
58.1	9535						413.33		do
	9536	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		431.11	423.70	
	9537						426.67		
58.2	9538						431.11		do
	9539	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9540						431.11		
59.1	9541						426.67		do
	9542	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	428.15	
	9543						431.11		
59.2	9544						431.11		do
	9545	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9546						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
60.1	9547						431.11		No. WRD/ SD I/WD XII/ F.47/335/2021-22. <b>DATED: 21-03-2022</b>
	9548	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9549						431.11		
60.2	9550						431.11		do
	9551	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9552						431.11		
61.1	9553						413.33		do
	9554	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		431.11	423.70	
	9555						426.67		
61.2	9556						431.11		do
	9557	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9558						431.11		
62.1	9559						426.67		do
	9560	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	428.15	
	9561						431.11		
62.2	9562						413.33		do
	9563	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		431.11	423.70	
	9564						426.67		
63.1	9565						431.11		do
	9566	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9567						431.11		
63.2	9568						426.67		do
	9569	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	428.15	
	9570						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
64.1	9571						431.11		No. WRD/ SD I/WD XII/ F.47/335/2021-22. <b>DATED: 21-03-2022</b>
	9572	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9573						431.11		
64.2	9574						431.11		do
	9575	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9576						431.11		
65.1	9577						413.33		do
	9578	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		431.11	423.70	
	9579						426.67		
65.2	9580						431.11		do
	9581	17-03-2022	14-04-2022	Rising Main delivery Tank -2 Raft	M30		426.67	429.63	
	9582						431.11		
66.1	9608						431.11		No. WRD/ SD I/WD XII/ F.47/13/2022-23. <b>DATED: 16-04-2022</b>
	9609	26-03-2022	23-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9610						431.11		
66.2	9611						431.11		do
	9612	26-03-2022	23-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9613						431.11		
67.1	9614						413.33		do
	9615	26-03-2022	23-04-2022	Rising Main delivery Tank -2 Wall	M30		431.11	423.70	
	9616						426.67		
67.2	9617						431.11		do
	9618	26-03-2022	23-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9619						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
68	9620						413.33		No. WRD/ SD I/WD XII/ F.47/13/2022-23. <b>DATED: 16-04-2022</b>
	9621	26-03-2022	23-04-2022	Rising Main delivery Tank -2 Wall	M30		431.11	423.70	
	9622						426.67		
69.1	9623						431.11		do
	9624	29-03-2022	26-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9625						431.11		
69.2	9626						426.67		do
	9627	29-03-2022	26-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	428.15	
	9628						431.11		
70.1	9629						426.67		do
	9630	29-03-2022	26-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	428.15	
	9631						431.11		
70.2	9632						431.11		do
	9633	29-03-2022	26-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9634						431.11		
71	9635						431.11		do
	9636	29-03-2022	26-04-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9637						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
72.1	9638						426.67		No. WRD/ SD I/WD XII/ F.47/13/2022-23. <b>DATED: 16-04-2022</b>
	9639	14-04-2022	12/5/2022	Rising Main delivery Tank -2 Wall	M30		426.67	428.15	
	9640						431.11		
72.2	9641						426.67		do
	9642	14-04-2022	12/5/2022	Rising Main delivery Tank -2 Wall	M30		426.67	428.15	
	9643						431.11		
73.1	9644						431.11		do
	9645	14-04-2022	12/5/2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9646						431.11		
73.2	9647						431.11		do
	9648	14-04-2022	12/5/2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9649						431.11		
74.1	9650						426.67		do
	9651	15-04-2022	13-05-2022	Rising Main delivery Tank -2 Wall	M30		431.11	428.15	
	9652						426.67		
74.2	9653						431.11		do
	9654	15-04-2022	13-05-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9655						431.11		
75.1	9656						426.67		do
	9657	15-04-2022	13-05-2022	Rising Main delivery Tank -2 Wall	M30		426.67	428.15	
	9658						431.11		
75.2	9659						431.11		do
	9660	15-04-2022	13-05-2022	Rising Main delivery Tank -2 Wall	M30		426.67	429.63	
	9661						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
76.1	9703						431.11		No. WRD/ SD I/WD XII/ F.47/42/2022-23. <b>DATED: 02-06-2022</b>
	9704	5/5/2022	2/6/2022	Sump Wall	M30		426.67	429.63	
	9705						431.11		
76.2	9706						431.11		do
	9707	5/5/2022	2/6/2022	Sump Wall	M30		426.67	429.63	
	9708						431.11		
76.3	9709						431.11		do
	9710	5/5/2022	2/6/2022	Sump Wall	M30		431.11	431.11	
	9711						431.11		
77.1	9712						431.11		do
	9713	6/5/2022	3/6/2022	Sump Wall	M30		426.67	429.63	
	9714						431.11		
77.2	9715						426.67		do
	9716	6/5/2022	3/6/2022	Sump Wall	M30		426.67	428.15	
	9717						431.11		
77.3	9718						426.67		do
	9719	6/5/2022	3/6/2022	Sump Wall	M30		431.11	428.15	
	9720						426.67		
78.1	9721						431.11		do
	9722	7/5/2022	4/6/2022	Sump Wall	M30		426.67	429.63	
	9723						431.11		
78.2	9724						426.67		do
	9725	7/5/2022	4/6/2022	Sump Wall	M30		426.67	428.15	
	9726						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
78.3	9727						431.11		No. WRD/ SD I/WD XII/ F.47/42/2022-23. <b>DATED: 02-06-2022</b>
	9728	7/5/2022	4/6/2022	Sump Wall	M30		431.11	431.11	
	9729						431.11		
79.1	9730						431.11		
	9731	8/5/2022	5/6/2022	Sump Wall	M30		426.67	429.63	do
	9732						431.11		
79.2	9733						426.67		
	9734	8/5/2022	5/6/2022	Sump Wall	M30		426.67	428.15	do
	9735						431.11		
79.3	9736						426.67		
	9737	8/5/2022	5/6/2022	Sump Wall	M30		426.67	428.15	do
	9738						431.11		
80.1	9739						431.11		
	9740	9/5/2022	6/6/2022	Sump Wall	M30		426.67	429.63	do
	9741						431.11		
80.2	9742						431.11		
	9743	9/5/2022	6/6/2022	Sump Wall	M30		426.67	429.63	do
	9744						431.11		
80.3	9745						431.11		
	9746	9/5/2022	6/6/2022	Sump Wall	M30		426.67	429.63	do
	9747						431.11		
81.1	9748						426.67		
	9749	10/5/2022	7/6/2022	Sump Wall	M30		426.67	428.15	do
	9750						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Lift Irrigation Scheme for Pumping of water from SIP main canal ( at Ch. 7 km) to delivery tank Ambetembo for distribution of water to Nagvem Molkarnem Zanodem Village Quepem Taluka for Irrigation Purpose.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
81.2	9751						426.67		No. WRD/ SD I/WD XII/ F.47/42/2022-23. <b>DATED: 02-06-2022</b>
	9752	10/5/2022	7/6/2022	Sump Wall	M30		426.67	428.15	
	9753						431.11		
81.3	9754						431.11		
	9755	10/5/2022	7/6/2022	Sump Wall	M30		426.67	429.63	do
	9756						431.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**