

**GOVERNMENT OF GOA**

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

Name of the Work :- Stabilization of RHS bank of waterways adjoining to the pond at Shivnagar in Xeldem Village of Quepem Taluka.

Sent by / Collected by :- Assistant Engineer, SD V, WD XII, WRD,Quepem-Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	1253						217.78		No. WRD/WD XII/SDV
	1254	16/01/2021	13-02-2021	foundation	1.2.4	210 kg/cm2	213.33	216.30	F.15/179/2020-21
	1255						217.78		<b>DATED: 21/01/2021</b>
2	1256						217.78		
	1257	18/01/2021	15-02-2021	1st lift	1.2.4	210 kg/cm2	222.22	219.26	do
	1258						217.78		
3	1259						217.78		
	1260	20/01/2021	17-02-2021	2nd and 3rd lift	1.2.4	210 kg/cm2	217.78	217.78	do
	1261						217.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

Name of the Work :- Stabilization of RHS bank of waterways adjoining to the pond at Shivnagar in Xeldem Village of Quepem Taluka.

Sent by / Collected by :- Assistant Engineer, SD V, WD XII, WRD,Quepem-Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1244						155.56		No. WRD/WD XII/SDV
1	1245	16/01/2021	23/01/2021	foundation	1.2.4	140 kg/cm2	160.00	155.56	F.15/179/2020-21
	1246						151.11		<b>DATED: 21/01/2021</b>
	1247						160.00		
2	1248	18/01/2021	25/01/2021	1st lift	1.2.4	140 kg/cm2	160.00	157.04	do
	1249						151.11		
	1250						155.56		
3	1251	20/01/2021	27/01/2021	2nd and 3rd lift	1.2.4	140 kg/cm2	160.00	155.56	do
	1252						151.11		

JUNIOR ENGINEER

ASSISTANT ENGINEER