## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T: 4870 & 4911/ Lab /125/ 2022 - 23 Dated: -15/06/2022.

Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

## Name of work: Construction of OT of Branch - 2 of Bastora Minor - 2 of LBMC of TIP at Bastora Village in Bardez Taluka.

Ref. to Requisition No.:SDI/WDVIII/WRD/WF.53/22-23/25 Dt.:- 17/ 05/ 2022

Oty. Recived.: 02 Sets of cube Date of Receipt:- 17/05/2022. Tested on: -10 & 13/06/2022 as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:2:4 O.S No. :8836 & 8881/SS Lab. Sample No.: 4511 to 4512 Tested By: Mrs. S.B. Naik Shirodkar J.E.

## **REPORT PAGE 01 OF 01**

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Valu e permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 13/05/2022. PCC for Chambers.	28 <sup>th</sup> day compressive strength <b>Average</b>	226.53 244.65 237.85 <b>236.34</b>	Ka/Cm <sup>2</sup> Ka/Cm <sup>2</sup> Kg/Cm <sup>2</sup> Ka/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	12.54	Oty represents - 5.00 Cum.
2	Cement concrete cube of mix 1:2:4, cast on 16/05/2022. PCC for Chambers.	28 <sup>th</sup> day compressive strength <b>Average</b>	217.47 240.12 235.59 <b>231.06</b>	Ka/Cm <sup>2</sup> Ka/Cm <sup>2</sup> Kg/Cm <sup>2</sup> Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	10.03	Oty represents - 5.00 Cum.

Copy to: 1. The Assistant Engineer , SD I , WDVIII , WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer, CPO, WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD VIII, WRD, Karaswada, Bardez Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer