

GOVERNMENT OF GOA
QUALITY CONTROL LABORATORY
WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 7233 / Lab / **200** / 2019 - 20 Dated:- 18/ 06 / 2019 Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work : Construction of Branches 1,2 & 3 and field channels of Bastora Minor - I off Taking at Ch. 33.610 km of LBMC of TIP at Bastora Village of Bardez Taluka.

Ref. to Requisition No.: WRD /WD VIII / SD III / W F.52 /2019-20/60 dated :-12 / 06 / 2019.

Qty. Recived. : 01 Set of cube Date of Receipt:- 14/ 06 / 2019. Tested on: - 14 /06/2019 Ref to CPWD :2002, Vol. I

Sample: Cube Mix 1 : 2 : 4 O.S No. : 2246/SS. Lab. Sample No.: 6125 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1 : 2 : 4 , cast on 07/06/2019, for retaining wall & trust Block. Qty represents - 15.00 Cum.(S1)	7 th day compressive strength	147.24	Kg/Cm ²	140.00 Kg/cm ²	8.41	28 th day test is due on 05/07/2019. The same may please be witnessed on due date.
			158.57	Kg/Cm ²			
			149.51	Kg/Cm ²			
		Average	151.77	Kg/Cm²			

Copy to: 1. The Assistant Engineer , SDIII , WD VIII, WRD, Karaswada, Bardez - Goa.

2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez - Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer