## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 7940,7942,7943 & 7947 / Lab / **296** / 2019 - 20 Dated: - 11 / 11 / 2019 Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Anjuna Distributory taking off at ch. 28.97 km of the Left bank main canal of Tillari Iirrigation Project in Siolim & Anjuna Village of Bardez Taluka. Part I: Construction of pump house, manifold and supply & installation of pumps and motors, Transformer Sub station, Electrical accessoriiies and internal wiring for Anjuna Distributory near Ch. 28.970 Kms of L.B.M.C. of T.I.P. at Cucholim Village of Bardez Taluka.

Ref. to Requisition No.: WRD /WD VIII / SD III / W F.32 /(PART -I)/2019-20/ 173 dated :- 31 / 10 / 2019.

Qty. Recived.: 04 Set of cube Date of Receipt:- 01 / 11 / 2019. Tested on: - 02 /11/2019 To 11/11/2019 as per due dates Ref to CPWD: 2002, Vol. I

Sample: Cube Mix 1:2:4 & 1:1.5:3 O.S No.: 2742,2745,2746 & 2748 /SS. Lab. Sample No.: 6864 To 6867 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable		REMARK
1	Cement concrete cube of mix <b>1:2:4</b> , cast on 05/10/2019, for Retaining wall at Carpenter - 1 <sup>St</sup> Lift. (S28)	28 <sup>th</sup> day	271.83	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	25.13	Qty represents -38.00 Cum.
		compressive	260.51	Kg/Cm <sup>2</sup>			
		strength	255.97	Kg/Cm <sup>2</sup>			
		Average	262.77	Kg/Cm <sup>2</sup>			
2	Reinforced Cement concrete cube of mix 1:1.5: 3, cast on 09/10/2019, for Columns C8 to C13 - First floor (S29)	28 <sup>th</sup> day	274.10	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	2.86	Qty represents - 4.00 Cum.
		compressive	278.63	Kg/Cm <sup>2</sup>			
		strength	265.04	Kg/Cm <sup>2</sup>			
		Average	272.59	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix <b>1:2:4</b> , cast on 11/10/2019, for Retaining wall at Carpenter - 2 <sup>nd</sup> Lift. (S30)	28 <sup>th</sup> day	260.51	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	22.97	Qty represents - 30.00 Cum.
		compressive	271.83	Kg/Cm <sup>2</sup>			
		strength	242.38	Kg/Cm <sup>2</sup>			
		Average	258.24	Kg/Cm <sup>2</sup>			
	Reinforced Cement concrete cube of mix 1:1.5: 3, cast on 14/10/2019, for Columns C15 to C20 & Cantilever slab at entrance.(S31)	28 <sup>th</sup> day	262.77	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	4.00	Qty represents - 7.00 Cum.
		compressive	280.89	Kg/Cm <sup>2</sup>			
		strength	283.16	Kg/Cm <sup>2</sup>			
		Average	275.61	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer , SDIII , WD VIII, WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

**Assistant Engineer**