GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 8839 & 8852 / Lab / **447** / 2019 - 20 Dated: - 22/02 / 2020 Laboratory : Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Providing Barbed wire fencing from ch. 24.080 km to 24.350 km of LBMC of TIP at Village Colvale in Bardez Taluka.

Ref. to Requisition No.: WRD /WD VIII / SD I / WF.41 /2019-20/190 dated :- 27/01 / 2020.

Qty. Recived.: 02 Sets of cube Date of Receipt:- 28 / 01 / 2020. Tested on: - 19 & 20 / 02/2020 as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:2:4 O.S No.: 3254 & 3269/SS. Lab. Sample No.: 7777 & 7778 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Plain Cement concrete cube of mix 1:2:4, cast on 22/01/2020, for retaining wall.	28 th day	203.87	Kg/Cm ²	210.00 Kg/cm ²	2.84	Qty represents - 7.00 Cum.
		compressive	215.20	Kg/Cm ²			
		strength	228.79	Kg/Cm ²			
		Average	215.95	Kg/Cm ²			
2	Plain Cement concrete cube of mix 1:2:4 , cast on 23/01/2020, for chamber wall.	28 th day	226.53	Kg/Cm ²	210.00 Kg/cm ²	4.63	Qty represents - 7.50 Cum.
		compressive	212.93	Kg/Cm ²			
		strength	219.73	Kg/Cm ²			
		Average	219.73	Kg/Cm ²			

Copy to: 1. The Assistant Engineer , SDI , WD VIII, WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer, CPO, WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer ,WD VIII ,WRD, Karaswada -Bardez Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer