GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :005 & 049 / Lab / **62** / 2020 - 21

Dated: 20 / 06 / 2020.

Laboratory: Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Field Chnnels from DWC 3Land 3L/3A takes off from Ch. 25.567 Km of LBMC of TIP at Colvale village of Bardez Taluka.

Ref. to Requisition No.: SD I/WD VIII/WRD/W. F.06/2020-21/57

Dated :- 12 / 06 / 2020.

Qty. Recived.: 02 Sets of cube Date of Receipt:- 15 / 06 / 2020. Tested on: - 15/06/2020 & 19/06/2020, as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:2:4 O.S No.: 3914 & 3950. Lab. Sample No.: 9229 & 9230 Tested By: Mrs. S. B. Naik Shirodkar, JE.

Cube test is wittnessed by Shri. Shinto John, representative by Agency Siddharth Bandekar, Santemol, Raia, Salcete Goa on 15/06/2020.

REPORT PAGE 01 OF 02

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1 1	Cement concrete cube of mix 1:2:4 , cast on 08/06/2020. PCC for beds of Chamber.	7 th day compressive	149.51 144.98	Kg/Cm ²	140.00 Kg/cm ²	7.33	 Qty represents - 13.00 Cum. 28 th day test is due on 06/07/2020, which may please be witnessed on due date.
		strength Average	156.30 150.26	Kg/Cm ²			
	Cement concrete cube of mix 1:2:4 , cast on 12/06/2020. PCC for wall Chamber & bed chamber.	7 th day compressive strength	140.45 160.83 135.92	Kg/Cm ² Kg/Cm ²	140.00 Kg/cm ²	4.09	 Qty represents - 13.00 Cum. 28 th day test is due on 10/07/2020, which may please be witnessed on due
		Average	145.73	Kg/Cm ²			date.

Copy to: 1. The Assistant Engineer , SD I , WD VIII, WRD, Karaswada, Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer , WD VIII ,WRD, Karaswada -Bardez $\,$ - Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer