GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T: 7932 & 7936 / Lab / **291** / 2019 - 20

Dated: 26/10 / 2019

Laboratory: Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of Outlets and R - Minor 6 taking off at ch. 7.38 km of SDC of LBMC of TIP at Sarvan, Bicholim Goa.

Ref. to Requisition No.: WRD /WD VIII / SD VI / F.257 / 2019-20 /87

dated :- 19 / 10 / 2019.

Qty. Recived.: 02 Sets of cube

Date of Receipt:- 22 / 10 / 2019. Tested on: -23/10 / 2019 & 26/10/2019 Ref to CPWD: 2002, Vol. I

Sample: Cube Mix 1:2:4 O.S No.: 2723 & 2732 /SS. Lab. Sample No.: 6853 & 6854 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Plain Cement concrete cube of mix 1:2:4 , cast	28 th day	258.24	Kg/Cm ²	210.00 Kg/cm ²	25.85	Qty represents - 14.50 Cum.
	on 25/09/2019, for Bed concrete below pipe of	compressive	271.83	Kg/Cm ²			
	outlets, Anchor blocks, Pillar of HRP and chambers	strength	262.77	Kg/Cm ²			
	at Outlet.	Average	264.28	Kg/Cm ²			
2	Plain Cement concrete cube of mix 1:2:4, cast	28 th day	262.77	Kg/Cm ²	210.00 Kg/cm ²	26.21	Qty represents - 14.80 Cum.
	on 28/09/2019, for Bed concrete below pipe of	compressive	260.51	Kg/Cm ²			
	outlets, Anchor blocks, Pillar of HRP and chambers	strength	271.83	Kg/Cm ²			
	at Outlet.	Average	265.04	Kg/Cm ²			

Copy to: 1. The Assistant Engineer , SDVI , WD VIII, WRD, Bicholim - Goa.

- 2. Copy submitted to The Superintending Engineer, CPO, WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD VIII, WRD, Karaswada -Bardez Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer