GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 7756,7757,7758 & 7794/ Lab / **251**/2019 - 20

 ${\sf Dated:-19/07/2019\ Laboratory:Bicholim-Goa.}$

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of Work: - Stabilisation unstable hill slope for the hill behind St. Mary High School at Altinho, Mapusa Bardez - Goa.

Ref. to Requisition no.: SDII/WDI/WRD/ F.24 /2019-20/200 dated:-05/07/2019.

Qty. Recived.: 04 Sets of cube Date of Receipt: 12/07/2019. Tested on: 13/06/2019 & 17/07/2019. Ref to CPWD: 2002, Vol. I

Sample: Cube **M-25** Mix O.S No. :2574,2575,2576 & 2607 /SS Lab. Sample No.: 6645 to 6648 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

| SR. NO. | DISCRIPTION OF SAMPLE | TESTED FOR | RESULTS | | Max./Min.Value permissable | % above or below | REMARK |
|------------|--|----------------------|---------|--------|----------------------------|--------------------------------|--------------------------------|
| 1 | Reinforced Cement concrete cube of mix M-25 cast on 15/06/2019. for Raft Slab of Cantilever retaining wall from Ch.17.10 to 32.25 m | 28 th day | 294.48 | Kg/Cm2 | 290.00 Kg/Cm ² | 5.71 | Quantity represents 15.00 Cum. |
| | | compressive | 303.55 | Kg/Cm2 | | | |
| | | strength | 321.67 | Kg/Cm2 | | | |
| | | Average | 306.57 | Kg/Cm2 | | | |
| 2 | Reinforced Cement concrete cube of mix M-25 cast on 15/06/2019. for Raft Slab of Cantilever retaining wall from Ch.17.10 to 32.25 m | 28 th day | 317.14 | Kg/Cm2 | 290.00 Kg/Cm ² | 6.23 | Quantity represents 15.00 Cum. |
| | | compressive | 310.34 | Kg/Cm2 | | | |
| | | strength | 296.75 | Kg/Cm2 | | | |
| | | Average | 308.08 | Kg/Cm2 | | | |
| 3 | Reinforced Cement concrete cube of mix M-25 cast on 15/06/2019. for Raft Slab of Cantilever retaining wall from Ch.17.10 to 32.25 m | 28 th day | 299.01 | Kg/Cm2 | 290.00 Kg/Cm ² | 7.80 | Quantity represents 13.80 Cum. |
| | | compressive | 305.81 | Kg/Cm2 | | | |
| | | strength | 332.99 | Kg/Cm2 | | | |
| | | Average | 312.61 | Kg/Cm2 | | | |
| 4 | Reinforced Cement concrete cube of mix M-25 cast on 19/06/2019. for Stem of Cantilever retaining wall from Ch.17.10 to 32.25 m | 28 th day | 317.14 | Kg/Cm2 | 290.00 Kg/Cm ² | 5.97 | Quantity represents 12.70 Cum. |
| | | compressive | 294.48 | Kg/Cm2 | | | |
| | | strength | 310.34 | Kg/Cm2 | | | |
| | | Average | 307.32 | Kg/Cm2 | | | |

Copy to: 1. The Assistant Engineer ,SD II,WD I,WRD, Mapusa - Goa.

- 2. Copy submitted to the Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to the Executive Engineer ,WD I,WRD, Porvorim Goa.
- 4. QC Lab File. 5. Bill File.