## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T: 055, 071 TO 074 / Lab / **69** / 2020 - 21

Dated:- 24/06/2020

Laboratory: Bicholim - Goa.
Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of pump house, Rising main and allied structures for pumping water from ch. 7.190 km to ch. 8.002 km and Gravity main from ch. 8.002 km to 8.780 km of B-6 Distributory of RBMC of TIP at Ugvem in Pernem Taluka.

Ref. to Requisition No.: SD II /WD VII /WRD/ F. 18 /2020-21/36 dated :- 18 / 06 / 2020.

Qty. Recived.: 05 Sets of cube Date of Receipt:- 19/06 / 2020. Tested on: - 19 & 20 /06 / 2020 as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:1.5:3 O.S No.: 3955,3970,3971,3972 & 3973 /SS. Lab. Sample No.: 9252 TO 9256

Tested By: Mrs. S.B. Naik Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
NO.		28 <sup>th</sup> day	204.49		permissable	DCIOW	
1 1	Cement concrete cube of mix 1:1.5:3, cast on 22/05/2020, RCC for Retaining wall RCC Raft.	•	294.48	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	6.28	Quantity represents 15.00 Cum
		compressive	278.63	Kg/Cm <sup>2</sup>			
		strength	271.83	Kg/Cm <sup>2</sup>			
		Average	281.65	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix 1:1.5:3, cast on 23/05/2020, RCC for Mat for sump for pump house at ch. 7.222km.	28 <sup>th</sup> day	280.89	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	7.14	Quantity represents 43.00 Cum for four sets of cubes
		compressive	271.83	Kg/Cm <sup>2</sup>			
		strength	299.01	Kg/Cm <sup>2</sup>			
		Average	283.91	Kg/Cm <sup>2</sup>			
	Cement concrete cube of mix 1:1.5:3, cast on 23/05/2020, RCC for Mat for sump for pump house at ch. 7.222km.	28 <sup>th</sup> day	303.55	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	12.27	do
		compressive	280.89	Kg/Cm <sup>2</sup>			
		strength	308.08	Kg/Cm <sup>2</sup>			
		Average	297.50	Kg/Cm <sup>2</sup>			
4	Cement concrete cube of mix 1:1.5:3, cast on 23/05/2020, RCC for Mat for sump for pump house at ch. 7.222km.	28 <sup>th</sup> day	289.95	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	9.99	do
		compressive	262.77	Kg/Cm <sup>2</sup>			
		strength	321.67	Kg/Cm <sup>2</sup>			
		Average	291.46	Kg/Cm <sup>2</sup>			
5	Cement concrete cube of mix 1:1.5:3, cast on 23/05/2020, RCC for Mat for sump for pump house at ch. 7.222km.	28 <sup>th</sup> day	294.48	Kg/Cm <sup>2</sup>	265.00 Kg/cm <sup>2</sup>	6.00	do
		compressive	280.89	Kg/Cm <sup>2</sup>			
		strength	267.30	Kg/Cm <sup>2</sup>			
		Average	280.89	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer , SDII , WD VII, WRD, Dhargal, Pernem - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer ,WD VII ,WRD, Dhargal, Pernem Goa.
- 4. QC Lab File. 5. Bill File.