## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / OC / F.6-2 / Cube -T : 1487,1507,1516,1556,1557 / Lab / **325** / 2020 - 21 Dated: - 12/04/ 2021. Laboratory : Bicholim - Goa. Sub Division V (OC)/WRD/ Bicholim- Goa.

Name of work: Construction of Anjuna Distributory taking off at ch.28.970km of the left Bank Main canal of Tillari irrigation Project in Siolim & Anjuna village of Bardez Taluka.part II: Construction of Rising Main and reinstatement of allied structures of Anjuna Distributory from ch.0.0kms to ch.4.50kms in Cucholim and Siolim village of Bardez Taluka.

Ref. to Requisition No.: SD III/WDVIII/WRD/WF.32(PART-II)/20-21/325 Dated: 24/03/2021.

Qty. Recived. :05 Sets of cube Date of Receipt:- 24/03/2021. Tested on: -25,26,27,29 & 30/03/2021 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix 1:2:4 O.S No.:5619,5642,5654,5695,5696/SS. Lab. Sample No.:998 to 1002 Tested By: Mrs. Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 18/03/2021.For R/wall at Cucholim bridge. Ch.0-28.0m bed PCC.	7 <sup>th</sup> day	144.98	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	14 88	1)Qty represents -19.50 Cum. 2)28th day test due on 15/04/2021.
		compressive	174.43	Kg/Cm <sup>2</sup>			
		strength	163.10	Kg/Cm <sup>2</sup>			
		Average	160.83	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix 1:2:4, cast on 19/03/2021.For R/wall at Cucholim bridge. Ch.28-60.0m bed PCC.	7 <sup>th</sup> day	156.30	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	ח לים	1)Qty represents -18.50 Cum. 2)28th day test due on 16/04/2021.
		compressive	135.92	Kg/Cm <sup>2</sup>			
		strength	154.04	Kg/Cm <sup>2</sup>			
		Average	148.75	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix 1:2:4, cast on 20/03/2021.For R/wall at Cucholim bridge. Ch.0-10.0m Foundation.	7 <sup>th</sup> day	140.45	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	14 34	1)Qty represents -20.00 Cum. 2)28th day test due on 17/04/2021.
		compressive	158.57	Kg/Cm <sup>2</sup>			
		strength	181.22	Kg/Cm <sup>2</sup>			
		Average	160.08	Kg/Cm <sup>2</sup>			
4	Cement concrete cube of mix 1:2:4, cast on 22/03/2021.For R/wall at Cucholim bridge. Ch.10-20.0m Foundation.	7 <sup>th</sup> day	167.63	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	1718	1)Qty represents -19.00 Cum. 2)28th day test due on 19/04/2021.
		compressive	147.24	Kg/Cm <sup>2</sup>			
		strength	156.30	Kg/Cm <sup>2</sup>			
		Average	157.06	Kg/Cm <sup>2</sup>			
5	Cement concrete cube of mix 1:2:4, cast on 23/03/2021.For R/wall at Cucholim bridge. Ch.20-30.0m Foundation.	7 <sup>th</sup> day	163.10	Kg/Cm <sup>2</sup>	140.00 Kg/cm <sup>2</sup>	1///	1)Qty represents -20.50 Cum. 2)28th day test due on 20/04/2021.
		compressive	154.04	Kg/Cm <sup>2</sup>			
		strength	156.30	Kg/Cm <sup>2</sup>		12.72	
		Average	157.81	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer, SD III, WD VIII, Karaswada-Bardez - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD VIII, Karaswada-Bardez Goa.
- 4. QC Lab File. 5. Bill File.