## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T :7821 & 7835 / Lab / **253** / 2019 - 20

Dated: 20/06/2019 Laboratory: Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of Work: - Construction of protection wall near Rampurush Bhawani Temple at Bagwada Agarwada V.P. Agarwada Chopde under Mandrem Constituency in Pernem Taluka.

Ref. to Requisition No.: MI/SDIII/WDI/WRD/W. F.32 /2019-20/ **90** Dated :- 24/06/2019.

Qty. Recived.: 02 Sets of cube Date of Receipt: 25/06/2019. Tested on: 19/06/2019 & 20/06/2019. Ref to CPWD: 2002, Vol. I

Sample: Cube 1:2:4 Mix O.S No.: 2634 & 2648/SS. Lab. Sample No.: 6506 & 6507 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

!	SR.N O.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
ſ	1	Cement concrete cube of mix 1:2:4, cast on 21/06/2019, For Second step Ch. 15.00 m To Ch. 40.00 m.	28 <sup>th</sup> day	226.53	Kg/Cm2	210 kg/cm2	8.59	Quantity represents 20.00 Cum
			compressive	244.65	Kg/Cm2			
			strength	212.93	Kg/Cm2			
L			Average	228.04	Kg/Cm2			
ſ	')	Cement concrete cube of mix 1:2:4, cast on 22/06/2019, For Third step Ch. 0.0 m To Ch. 40.00 m.	28 <sup>th</sup> day	237.85	Kg/Cm2	- 210 kg/cm2	7.51	Quantity represents 15.00 Cum
			compressive	226.53	Kg/Cm2			
			strength	212.93	Kg/Cm2			
			Average	225.77	Kg/Cm2			

Copy to: 1. The Assistant Engineer ,SD III,WD I,WRD, Pernem - Goa.

2. Copy submitted to the Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.

3. Copy submitted to the Executive Engineer ,WD I,WRD, Porvorim Goa.

4. QC Lab File. 5. Bill File.

Junior Engineer

**Assistant Engineer**