## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 2640,2641,2642,2645 / Lab / **167** / 2021 - 22 Dated:-03/08/2021. Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

## Name of work: Renovation of Talli at Gaonkarwada in V.P.Betqui Candoal in Priol Constituency.

Ref. to Requisition No.: WRD/WDXI/SDIV/F.488/182/2021-22 Dated :- 12/07/2021.

Qty. Recived. :04 Sets of cube Date of Receipt:- 27/07/ 2021. Tested on: -27,28,29,31/07/2021 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC 1: 2: 4 O.S No.: 6878,6879,6880,6885/SS. Lab. Sample No.: 2129 To 2132 Tested By: Mrs. Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or <del>below</del>	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 29/06/2021. P.C.C. for foundation.	28 <sup>th</sup> day	215.20	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	4.27	1)Qty represents -20.00 Cum. 2)Exact location of work done is not mentioned.
		compressive	217.47	Kg/Cm <sup>2</sup>			
		strength	224.26	Kg/Cm <sup>2</sup>			
		Average	218.98	Kg/Cm <sup>2</sup>			
2	Cement concrete cube of mix 1:2:4, cast on 30/06/2021. P.C.C. for Base.	28 th day	208.40	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	5.71	do
		compressive	226.53	Kg/Cm <sup>2</sup>			
		strength	231.06	Kg/Cm <sup>2</sup>			
		Average	222.00	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix 1:2:4, cast on 01/07/2021. P.C.C. for Side wall.	28 th day	228.79	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	10.03	do
		compressive	219.73	Kg/Cm <sup>2</sup>			
		strength	244.65	Kg/Cm <sup>2</sup>			
		Average	231.06	Kg/Cm <sup>2</sup>			
4	Cement concrete cube of mix 1:2:4, cast on 03/07/2021. P.C.C. for Side wall.	28 th day	215.20	Kg/Cm <sup>2</sup>	210.00 Kg/cm <sup>2</sup>	8.95	do
		compressive	233.32	Kg/Cm <sup>2</sup>			
		strength	237.85	Kg/Cm <sup>2</sup>			
		Average	228.79	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer, SD IV, WD XI, WRD, Ponda - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD XI, WRD, Ravonfond-Navelim-Salcete Goa.
- 4. QC Lab File. 5. Bill File.