GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 3123,3128,3137 & 3144 / Lab /297/ 2021 - 22 Dated: - 11/02 /2022.

Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: "Improvement and Development of Veling Talli at Talewada in Survey No.22/0, of Veling Village in Priol Constituency."

Ref. to Requisition No.: WRD/WDXI/SDIV/W.F.464/453/2021-22 Dt.:- 17/ 01/ 2022

Qty. Recived. :04 Sets of cube Date of Receipt:- 17/01/2022. Tested on: -07,08,09 & 10/02/2022 as per due dates. Ref to CPWD :2009, Vol. I

Sample: Cube Mix PCC 1: 2: 4 O.S No.: 7590,7598,7607 &7615/SS. Lab. Sample No.: 2762 To 2765 Tested By: Mrs. S.B. Naik Shirodkar. J.E.

REPORT PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1	Cement concrete cube of mix 1:2:4, cast on 10/01/2022. P.C.C. For foundation.	28 th day compressive strength Average	217.47 212.93 228.79 219.73	Kg/Cm ² Kg/Cm ² Kg/Cm ² Kg/Cm ²	210.00 Kg/cm ²	4.63	1)Qty represents -20.00 Cum. 2)Exact location of work done is not mentioned.
2	Cement concrete cube of mix 1:2:4, cast on 11/01/2022. P.C.C. For foundation.	compressive strength Average	215.20 231.06 240.12 228.79	Kg/Cm ² Kg/Cm ² Kg/Cm ² Kg/Cm ²	210.00 Kg/cm ²	8.95	1)Qty represents -20.00 Cum. 2)Exact location of work done is not mentioned.
3	Cement concrete cube of mix 1:2:4, cast on 12/01/2022. P.C.C. For foundation.	28 th day compressive strength Average	237.85 226.53 231.06 231.81	Kg/Cm ² Kg/Cm ² Kg/Cm ² Kg/Cm ²	210.00 Kg/cm ²	10.39	1)Qty represents -20.00 Cum. 2)Exact location of work done is not mentioned.
4	Cement concrete cube of mix 1:2:4 , cast on 13/01/2022. P.C.C. For foundation.	28 th day compressive strength Average	226.53 215.20 215.20 218.98	$\frac{\text{Kg/Cm}^2}{\text{Kg/Cm}^2}$ $\frac{\text{Kg/Cm}^2}{\text{Kg/Cm}^2}$	210.00 Kg/cm ²	4.27	1)Qty represents -20.00 Cum. 2)Exact location of work done is not mentioned.

Copy to: 1. The Assistant Engineer, SD IV, WD XI, WRD, Ponda - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD XI, WRD, Ravonfond-Navelim-Salcete Goa.
- 4. QC Lab File. 5. Bill File.