## GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No: WRD/QC/F.6-2/Cube -T: 5505,5506,5507,5508/Lab/**208**/2022 - 23 Dated: - 13/12/2022. Laboratory: Bicholim - Goa.

Sub Division V (QC)/WRD/ Bicholim- Goa.

## Name of work: Construction of 30 MLD Raw Water Pumping Station at Calangute on Calangute distributary of Tillari Canal for Pilerne Industrial Estate and Surrounding Villages of Calangute and Saligao.

Ref. to Requisition No: SDV/WDI/WRD/F.27/2022-23/210 dated: -09/12/2022.

Oty. Recived: 04 Set of cube Date of Receipt:- 09/12/2022 Tested on: - 09/12/2022. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix **M25** O.S No.: 9541,9542,9543,9544/SS Lab. Sample No.: 5472 To 5475. Tested By: Mrs. S.B. Naik Shirodkar. J.E.

## **REPORT PAGE 01 OF 01**

SR.N	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value	% above or	REMARK
1	Cement concrete cube of mix <b>M25</b> , cast on 11/11/2022. Haunch for delivery tank.	28 <sup>th</sup> day compressive strength	280.89 317.14 351.12	Kg/Cm <sup>2</sup> Kg/Cm <sup>2</sup> Kg/Cm <sup>2</sup>	290.00 Kg/cm <sup>2</sup>	9.10	Oty represents - 48.00 cum. for Four Sets of Cube.
		Average	316.38	Kq/Cm <sup>2</sup>			
2	Cement concrete cube of mix <b>M25</b> , cast on 11/11/2022. Haunch for delivery tank.	28 <sup>th</sup> day	317.14	Kg/Cm <sup>2</sup>	290.00 Kg/cm <sup>2</sup>	10.66	do
		compressive	308.08	Kg/Cm <sup>2</sup>			
		strength	337.52	Kg/Cm <sup>2</sup>			
		Average	320.91	Kg/Cm <sup>2</sup>			
3	Cement concrete cube of mix <b>M25</b> , cast on 11/11/2022. Haunch for delivery tank.	28 <sup>th</sup> day	348.85	Kg/Cm <sup>2</sup>	290.00 Kg/cm <sup>2</sup>	23.94	do
		compressive	351.12	Kg/Cm <sup>2</sup>			
		strength	378.30	Kg/Cm <sup>2</sup>			
		<b>Average</b>	359.42	Kg/Cm <sup>2</sup>			
4	Cement concrete cube of mix <b>M25</b> , cast on 11/11/2022. Haunch for delivery tank.	28 <sup>th</sup> day	296.75	Kg/Cm <sup>2</sup>	290.00 Kg/cm <sup>2</sup>	16.65	do
		compressive	355.65	Kg/Cm <sup>2</sup>			
		strength	362.44	Kg/Cm <sup>2</sup>			
		Average	338.28	Kg/Cm <sup>2</sup>			

Copy to: 1. The Assistant Engineer, SD V, WD I, WRD, Porvorim - Goa.

- 2. Copy submitted to The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to The Executive Engineer, WD I, WRD, Porvorim Goa.
- 4. QC Lab File. 5. Bill File.