

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD			28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	164						186.67		No. WRD/ WD XII/ SD V/ F.15/153/2020-21. <b>DATED: 08-12-2020</b>
	165	1/12/2020	29-12-2020	Foundation	1.2.4	150 kg/cm2	182.22	183.70	
	166						182.22		
1.2	167						182.22		do
	168	1/12/2020	29-12-2020	Foundation	1.2.4	150 kg/cm2	186.67	185.19	
	169						186.67		
2.1	170						182.22		do
	171	2/12/2020	30-12-2020	Foundation	1.2.4	150 kg/cm2	182.22	183.70	
	172						186.67		
2.2	173						177.78		do
	174	2/12/2020	30-12-2020	Foundation	1.2.4	150 kg/cm2	186.67	183.71	
	175						186.67		
3.1	176						173.33		do
	177	3/12/2020	31-12-2020	Foundation	1.2.4	150 kg/cm2	173.33	174.81	
	178						177.78		
3.2	179						173.33		do
	180	3/12/2020	31-12-2020	Foundation	1.2.4	150 kg/cm2	168.89	171.85	
	181						173.33		
4.1	182						177.78		do
	183	4/12/2020	1/1/2021	Foundation	1.2.4	150 kg/cm2	173.33	174.81	
	184						173.33		
4.2	185						173.33		do
	186	4/12/2020	1/1/2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	187						173.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	188						168.89		No. WRD/ WD XII/ SD V/ F.15/153/2020-21. <b>DATED: 08-12-2020</b>
	189	5/12/2020	2/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	190						173.33		
5.2	191						173.33		do
	192	5/12/2020	2/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	171.85	
	193						173.33		
6.1	434						164.44		No. WRD/ WD XII/ SD V/ F.15/157/2020-21. <b>DATED: 14-12-2020</b>
	435	8/12/2020	5/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	436						168.89		
6.2	437						164.44		do
	438	8/12/2020	5/1/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	439						168.89		
7.1	440						177.78		do
	441	9/12/2020	6/1/2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	442						168.89		
7.2	443						173.33		do
	444	9/12/2020	6/1/2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	445						168.89		
8.1	446						173.33		do
	447	10/12/2020	7/1/2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	448						173.33		
8.2	449						177.78		do
	450	10/12/2020	7/1/2021	Foundation	1.2.4	150 kg/cm2	173.33	174.81	
	451						173.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	452						173.33		No. WRD/ WD XII/ SD V/ F.15/157/2020-21. <b>DATED: 14-12-2020</b>
	453	11/12/2020	8/1/2021	1st Lift	1.2.4	150 kg/cm2	168.89	171.85	
	454						173.33		
9.2	455						168.89		do
	456	11/12/2020	8/1/2021	1st Lift	1.2.4	150 kg/cm2	173.33	170.37	
	457						168.89		
10.1	458						173.33		do
	459	12/12/2020	9/1/2021	1st Lift	1.2.4	150 kg/cm2	173.33	171.85	
	460						168.89		
10.2	461						173.33		do
	462	12/12/2020	9/1/2021	1st Lift	1.2.4	150 kg/cm2	173.33	173.33	
	463						173.33		
11	1124						160.00		No. WRD/ WD XII/ SD V/ F.15/174/2020-21. <b>DATED: 15-01-2021</b>
	1125	8/1/2021	5/2/2021	2nd Lift	1.2.4	150 kg/cm2	160.00	160.00	
	1126						160.00		
12	1127						160.00		do
	1128	9/1/2021	6/2/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	158.52	
	1129						155.56		
13	1130						160.00		do
	1131	11/1/2021	8/2/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	158.52	
	1132						155.56		
14	1133						160.00		do
	1134	12/1/2021	9/2/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	160.00	
	1135						160.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15	1136						160.00		No. WRD/ WD XII/ SD V/ F.15/174/2020-21. <b>DATED: 15-01-2021</b>
	1137	13-01-2021	10/2/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	158.52	
	1138						155.56		
16	1139						160.00		do
	1140	14-01-2021	11/2/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	160.00	
	1141						160.00		
17.1	1850						168.89		No. WRD/ WD XII/ SD V/ F.15/189/2020-21. <b>DATED: 10-02-2021</b>
	1851	27-01-2021	24-02-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	170.37	
	1852						173.33		
17.2	1853						173.33		do
	1854	27-01-2021	24-02-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	171.85	
	1855						173.33		
18.1	1856						164.44		do
	1857	28-01-2021	25-02-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	1858						168.89		
18.2	1859						164.44		do
	1860	28-01-2021	25-02-2021	3rd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	1861						168.89		
19.1	1862						177.78		do
	1863	29-01-2021	26-02-2021	3rd Lift	1.2.4	150 kg/cm2	173.33	173.33	
	1864						168.89		
19.2	1865						173.33		do
	1866	29-01-2021	26-02-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	170.37	
	1867						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
20.1	1868						173.33		No. WRD/ WD XII/ SD V/ F.15/189/2020-21. <b>DATED: 10-02-2021</b>
	1869	30-01-2021	27-02-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	171.85	
	1870						173.33		
20.2	1871						168.89		
	1872	30-01-2021	27-02-2021	3rd Lift	1.2.4	150 kg/cm2	173.33	170.37	do
	1873						168.89		
21.1	1874						173.33		
	1875	1/2/2021	1/3/2021	3rd Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	1876						168.89		
21.2	1877						173.33		
	1878	1/2/2021	1/3/2021	3rd Lift	1.2.4	150 kg/cm2	173.33	173.33	do
	1879						173.33		
23.1	1880						160.00		
	1881	2/2/2021	2/3/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	160.00	do
	1882						160.00		
23.2	1883						160.00		
	1884	2/2/2021	2/3/2021	3rd Lift	1.2.4	150 kg/cm2	160.00	158.52	do
	1885						155.56		
24	1886						160.00		
	1887	3/2/2021	3/3/2021	4th Lift	1.2.4	150 kg/cm2	160.00	158.52	do
	1888						155.56		
25	1889						160.00		
	1890	4/2/2021	4/3/2021	4th Lift	1.2.4	150 kg/cm2	160.00	160.00	do
	1891						160.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
26	1892						160.00		No. WRD/ WD XII/ SD V/ F.15/189/2020-21. <b>DATED: 10-02-2021</b>
	1893	5/2/2021	5/3/2021	4th Lift	1.2.4	150 kg/cm2	160.00	158.52	
	1894						155.56		
27	1895						160.00		do
	1896	8/2/2021	8/3/2021	5th Lift	1.2.4	150 kg/cm2	160.00	158.52	
	1897						155.56		
28	2099						168.89		No. WRD/ WD XII/ SD V/ F.15/191/2020-21. <b>DATED: 19-02-2021</b>
	2100	15-02-2021	15-03-2021	4th Lift	1.2.4	150 kg/cm2	168.89	168.89	
	2101						168.89		
29	2102						168.89		do
	2103	16-02-2021	16-03-2021	5th Lift	1.2.4	150 kg/cm2	173.33	171.85	
	2104						173.33		
30	2105						173.33		do
	2106	18-02-2021	18-03-2021	6th Lift	1.2.4	150 kg/cm2	173.33	174.81	
	2107						177.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
31.1	2798						168.89		No. WRD/ WD XII/ SD V/ F.15/196/2020-21. <b>DATED: 08-03-2021</b>
	2799	27-02-2021	27-03-2021	5th Lift	1.2.4	150 kg/cm2	173.33	171.85	
	2800						173.33		
31.2	2801						173.33		
	2802	27-02-2021	27-03-2021	5th Lift	1.2.4	150 kg/cm2	173.33	173.33	do
	2803						173.33		
32.1	2804						168.89		
	2805	1/3/2021	29-03-2021	5th Lift	1.2.4	150 kg/cm2	173.33	171.85	do
	2806						173.33		
32.2	2807						168.89		
	2808	1/3/2021	29-03-2021	5th Lift	1.2.4	150 kg/cm2	173.33	170.37	do
	2809						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**