

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD			07 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	134						111.11		No. WRD/ WD XII/ SD V/ F.15/153/2020-21. DATED: 08-12-2020
	135	1/12/2020	8/12/2020	Foundation	1.2.4	100 kg/cm2	111.11	108.30	
	136						102.67		
1.2	137						106.67		do
	138	1/12/2020	8/12/2020	Foundation	1.2.4	100 kg/cm2	106.67	108.15	
	139						111.11		
2.1	140						106.67		do
	141	2/12/2020	9/12/2020	Foundation	1.2.4	100 kg/cm2	111.11	108.15	
	142						106.67		
2.2	143						106.67		do
	144	2/12/2020	9/12/2020	Foundation	1.2.4	100 kg/cm2	106.67	106.67	
	145						106.67		
3.1	146						111.11		do
	147	3/12/2020	10/12/2020	Foundation	1.2.4	100 kg/cm2	111.11	109.63	
	148						106.67		
3.2	149						102.27		do
	150	3/12/2020	10/12/2020	Foundation	1.2.4	100 kg/cm2	106.60	106.66	
	151						111.11		
4.1	152						106.67		do
	153	4/12/2020	11/12/2020	Foundation	1.2.4	100 kg/cm2	97.78	102.24	
	154						102.27		
4.2	155						106.67		do
	156	4/12/2020	11/12/2020	Foundation	1.2.4	100 kg/cm2	102.27	105.20	
	157						106.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	158						106.67		No. WRD/ WD XII/ SD V/ F.15/153/2020-21. DATED: 08-12-2020
	159	5/12/2020	12/12/2020	Foundation	1.2.4	100 kg/cm2	106.67	105.20	
	160						102.27		
5.2	161						106.67		do
	162	5/12/2020	12/12/2020	Foundation	1.2.4	100 kg/cm2	106.67	106.67	
	163						106.67		
6.1	404						106.67		No. WRD/ WD XII/ SD V/ F.15/157/2020-21. DATED: 14-12-2020
	405	8/12/2020	15-12-2020	Foundation	1.2.4	100 kg/cm2	111.11	108.15	
	406						106.67		
6.2	407						106.67		do
	408	8/12/2020	15-12-2020	Foundation	1.2.4	100 kg/cm2	106.67	108.15	
	409						111.11		
7.1	410						106.67		do
	411	9/12/2020	16-12-2020	Foundation	1.2.4	100 kg/cm2	106.67	105.20	
	412						102.27		
7.2	413						111.11		do
	414	9/12/2020	16-12-2020	Foundation	1.2.4	100 kg/cm2	106.67	108.15	
	415						106.67		
8.1	416						106.67		do
	417	10/12/2020	17-12-2020	Foundation	1.2.4	100 kg/cm2	102.27	105.20	
	418						106.67		
8.2	419						106.67		do
	420	10/12/2020	17-12-2020	Foundation	1.2.4	100 kg/cm2	111.11	108.15	
	421						106.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	422						106.67		No. WRD/ WD XII/ SD V/ F.15/157/2020-21. DATED: 14-12-2020
	423	11/12/2020	18-12-2020	1st Lift	1.2.4	100 kg/cm2	111.11	109.63	
	424						111.11		
9.2	425						111.11		do
	426	11/12/2020	18-12-2020	1st Lift	1.2.4	100 kg/cm2	111.11	111.11	
	427						111.11		
10.1	428						111.11		do
	429	12/12/2020	19-12-2020	1st Lift	1.2.4	100 kg/cm2	106.67	109.63	
	430						111.11		
10.2	431						106.67		do
	432	12/12/2020	19-12-2020	1st Lift	1.2.4	100 kg/cm2	106.67	108.15	
	433						111.11		
11	1106						111.11		No. WRD/ WD XII/ SD V/ F.15/174/2020-21. DATED: 15-01-2021
	1107	8/1/2021	15-01-2021	2nd Lift	1.2.4	100 kg/cm2	111.11	111.11	
	1108						111.11		
12	1109						106.67		do
	1110	9/1/2021	16-01-2021	3rd Lift	1.2.4	100 kg/cm2	106.67	108.15	
	1111						111.11		
13	1112						111.11		do
	1113	11/1/2021	18-01-2021	3rd Lift	1.2.4	100 kg/cm2	111.11	108.15	
	1114						102.22		
14	1115						120.00		do
	1116	12/1/2021	19-01-2021	3rd Lift	1.2.4	100 kg/cm2	115.56	117.04	
	1117						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15	1118						115.56		No. WRD/ WD XII/ SD V/ F.15/174/2020-21. DATED: 15-01-2021
	1119	13-01-2021	20-01-2021	3rd Lift	1.2.4	100 kg/cm2	115.56	115.56	
	1120						115.56		
16	1121						111.11		do
	1122	14-01-2021	21-01-2021	3rd Lift	1.2.4	100 kg/cm2	111.11	109.63	
	1123						106.67		
17	1838						106.67		No. WRD/ WD XII/ SD V/ F.15/189/2020-21. DATED: 10-02-2021
	1839	3/2/2021	10/2/2021	4th Lift	1.2.4	100 kg/cm2	111.11	109.63	
	1840						111.11		
18	1841						111.11		do
	1842	4/2/2021	11/2/2021	4th Lift	1.2.4	100 kg/cm2	111.11	111.11	
	1843						111.11		
19	1844						111.11		do
	1845	5/2/2021	12/2/2021	4th Lift	1.2.4	100 kg/cm2	106.67	109.63	
	1846						111.11		
20	1847						106.67		do
	1848	8/2/2021	15-02-2021	5th Lift	1.2.4	100 kg/cm2	106.67	108.15	
	1849						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of protection wall to the side bank of nallah at Rawabhat Shirvoi in ward No. 2 in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
21	2090						120.00		No. WRD/ WD XII/ SD V/
	2091	15-02-2021	22-02-2021	4th Lift	1.2.4	100 kg/cm ²	115.56	117.04	F.15/191/2020-21.
	2092						115.56		DATED: 19-02-2021
22	2093						115.56		
	2094	16-02-2021	23-02-2021	5th Lift	1.2.4	100 kg/cm ²	115.56	115.56	do
	2095						115.56		
23	2096						115.56		
	2097	18-02-2021	25-02-2021	6th Lift	1.2.4	100 kg/cm ²	120.00	117.04	do
	2098						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER