

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	554						164.44		No. WRD/SD I/ WD II/ F.Esst/406/2021-22 DATED:- 13-12-2021.
	555	6/12/2021	3/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	556						168.89		
2	557						164.44		do
	558	8/12/2021	5/1/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	559						164.44		
3	560						164.44		do
	561	10/12/2021	7/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	562						168.89		
4	563						168.89		do
	564	11/12/2021	8/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	565						168.89		
5.1	782						164.44		No. WRD/SD I/ WD II/ F.Esst/669/2021-22 DATED:- 05-01-2022.
	783	13-12-2021	10/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	784						168.89		
5.2	785						164.44		do
	786	13-12-2021	10/1/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	787						164.44		
6.1	788						164.44		do
	789	14-12-2021	11/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	790						168.89		
6.2	791						168.89		do
	792	14-12-2021	11/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	793						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	794						164.44		No. WRD/SD I/ WD II/ F.Esst/669/2021-22 DATED:- 05-01-2022.
	795	15-12-2021	12/1/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	796						164.44		
7.2	797						164.44		do
	798	15-12-2021	12/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	799						168.89		
8.1	800						168.89		do
	801	16-12-2021	13-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	802						164.44		
8.2	803						164.44		do
	804	16-12-2021	13-01-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	805						164.44		
9.1	806						164.44		do
	807	17-12-2021	14-01-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	808						164.44		
9.2	809						164.44		do
	810	17-12-2021	14-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	811						168.89		
10.1	812						168.89		do
	813	18-12-2021	15-01-2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	814						168.89		
102	815						168.89		do
	816	18-12-2021	15-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	817						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.1	818						164.44		No. WRD/SD I/ WD II/ F.Esst/669/2021-22 DATED:- 05-01-2022.
	819	20-12-2021	17-01-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	
	820						164.44		
11.2	821						168.89		do
	822	20-12-2021	17-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	823						164.44		
12.1	824						164.44		do
	825	21-12-2021	18-01-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	826						164.44		
12.2	827						164.44		do
	828	21-12-2021	18-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	829						168.89		
13.1	830						168.89		do
	831	22-12-2021	19-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	832						164.44		
13.2	833						164.44		do
	834	22-12-2021	19-01-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	835						164.44		
14.1	836						164.44		do
	837	23-12-2021	20-01-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	838						164.44		
14.2	839						164.44		do
	840	23-12-2021	20-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	841						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15.1	842						164.44		No. WRD/SD I/ WD II/
	843	24-12-2021	21-01-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	F.Esst/669/2021-22
	844						164.44		DATED:- 05-01-2022.
15.2	845						164.44		
	846	24-12-2021	21-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	847						168.89		
16.1	909						164.44		No. WRD/SD I/ WD II/
	910	30-12-2021	27-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	F.Esst/700/2021-22
	911						168.89		DATED:- 20-01-2022.
16.2	912						168.89		
	913	30-12-2021	27-01-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	914						164.44		
17.1	915						164.44		
	916	31-12-2021	28-01-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	917						168.89		
17.2	918						168.89		
	919	31-12-2021	28-01-2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	920						164.44		
18.1	921						168.89		
	922	1/1/2022	29-01-2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	923						164.44		
18.2	924						168.89		
	925	1/1/2022	29-01-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	926						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.1	927						168.89		No. WRD/SD I/ WD II/ F.Esst/700/2021-22 DATED:- 20-01-2022.
	928	3/1/2022	31-01-2022	Wall	1.2.4	150 kg/cm2	168.89	165.93	
	929						160.00		
19.2	930						164.44		
	931	3/1/2022	31-01-2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	932						164.44		
20.1	933						164.44		
	934	4/1/2022	1/2/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	935						164.44		
20.2	936						164.44		
	937	4/1/2022	1/2/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	do
	938						164.44		
21.1	939						168.89		
	940	5/1/2022	2/2/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	do
	941						168.89		
21.2	942						168.89		
	943	5/1/2022	2/2/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	do
	944						168.89		
22.1	945						164.44		
	946	6/1/2022	3/2/2022	Wall	1.2.4	150 kg/cm2	164.44	164.44	do
	947						164.44		
22.2	948						164.44		
	949	6/1/2022	3/2/2022	Wall	1.2.4	150 kg/cm2	168.89	165.92	do
	950						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
23.1	951						168.89		No. WRD/SD I/ WD II/ F.Esst/700/2021-22 DATED:- 20-01-2022.
	952	7/1/2022	4/2/2021	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	953						168.89		
23.2	954						168.89		do
	955	7/1/2022	4/2/2021	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	956						168.89		
24.1	957						168.89		do
	958	8/1/2022	5/2/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	959						168.89		
24.2	960						168.89		do
	961	8/1/2022	5/2/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	962						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER