

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	6209						164.44		No. WRD/WD XII/ SD V/ F.15/09/2021-22. DATED: 15-04-2021
	6210	9/4/2021	7/5/2021	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	6211						164.44		
1.2	6212						168.89		do
	6213	9/4/2021	7/5/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	6214						164.44		
1.3	6215						164.44		do
	6216	9/4/2021	7/5/2021	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	6217						164.44		
2.1	6218						164.44		do
	6219	10/4/2021	8/5/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	6220						168.89		
2.2	6221						168.89		do
	6222	10/4/2021	8/5/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	6223						164.44		
2.3	6224						164.44		do
	6225	10/4/2021	8/5/2021	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	6226						164.44		
3.1	6227						164.44		do
	6228	11/4/2021	9/5/2021	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	6229						164.44		
3.2	6230						164.44		do
	6231	11/4/2021	9/5/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	6232						168.89		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	6233						164.44		No. WRD/WD XII/ SD V/ F.15/09/2021-22. DATED: 15-04-2021
	6234	12/4/2021	10/5/2021	1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	6235						164.44		
4.2	6236						164.44		do
	6237	12/4/2021	10/5/2021	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6238						168.89		
5.1	6239						168.89		do
	6240	14-04-2021	12/5/2021	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6241						164.44		
5.2	6242						164.44		do
	6243	14-04-2021	12/5/2021	1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	6244						164.44		
5.3	6245						164.44		do
	6246	14-04-2021	12/5/2021	1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	6247						164.44		
6.1	6134						164.44		No. WRD/WD XII/ SD V/ F.15/14/2021-22. DATED: 21-04-2021
	6135	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6136						168.89		
6.2	6137						168.89		do
	6138	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	167.41	
	6139						168.89		
6.3	6140						168.89		do
	6141	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6142						164.44		

**Sandip Parab
JUNIOR ENGINEER.**

**Pravin C Parsekar
ASSISTANT ENGINEER**

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.4	6143						164.44		No. WRD/WD XII/ SD V/ F.15/14/2021-22. DATED: 21-04-2021
	6144	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	160.00	162.96	
	6145						164.44		
6.5	6146						164.44		do
	6147	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6148						168.89		
6.6	6149						164.44		do
	6150	16-04-2021	14-05-2021	2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6151						168.89		
7.1	6152						168.89		do
	6153	17-04-2021	15-05-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	6154						164.44		
7.2	6155						164.44		do
	6156	17-04-2021	15-05-2021	3rd Lift	1.2.4	150 kg/cm2	164.44	165.92	
	6157						168.89		
7.3	6158						168.89		do
	6159	17-04-2021	15-05-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	6160						164.44		
7.4	6161						168.89		do
	6162	17-04-2021	15-05-2021	3rd Lift	1.2.4	150 kg/cm2	168.89	167.41	
	6163						164.44		
8	6164						168.89		do
	6165	19-04-2021	17-05-2021	4th lift Middle band	1.2.4	150 kg/cm2	164.44	165.92	
	6166						164.44		

**Sandip Parab
JUNIOR ENGINEER.**

**Pravin C Parsekar
ASSISTANT ENGINEER**

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
9	6167						168.89		No. WRD/WD XII/ SD V/
	6168	20-04-2021	18-05-2021	2nd Lift	1.2.4	150 kg/cm ²	168.89	167.41	F.15/14/2021-22.
	6169						164.44		DATED: 21-04-2021

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER