

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of 45 Nos. RCC open shallow wells at various locations in Nuvem Constituency Salcete Taluka Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao - Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	6938						231.11		No. 270/T/SD III/ WD III/WRD/2021-22/49 DATED: 07-05-2021
	6939	29-04-2021	27-05-2021	Well curb	1.1.5.3	200 kg/cm ²	231.11	232.59	
	6940						235.56		
2	6941						235.56		do
	6942	3/5/2021	31-05-2021	Well rings	1.1.5.3	200 kg/cm ²	231.11	234.08	
	6943						235.56		
3	7691						226.67		No. 270/T/SD III/ WD III/WRD/2021-22/69 DATED: 29-05-2021
	7692	7/5/2021	4/6/2021	Well curb, Well rings	1.1.5.3	200 kg/cm ²	231.11	231.11	
	7693						235.56		
4	7694						231.11		do
	7695	13-05-2021	10/6/2021	Well rings	1.1.5.3	200 kg/cm ²	235.56	231.11	
	7696						226.67		
5	7697						235.56		do
	7698	19-05-2021	16-06-2021	Well rings	1.1.5.3	200 kg/cm ²	235.56	234.08	
	7699						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER