

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	4265						75.56		No. WRD/SD I/WD II/ F.Estt/940/2020-21. DATED: 24-03-2021
	4266	19-03-2021	26-03-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	4267						75.56		
2	4268						75.56		do
	4269	20-03-2021	27-03-2021	Foundation	1.3.6	70 kg/cm2	66.65	74.07	
	4270						80.00		
3	4271						75.56		do
	4272	21-03-2021	28-03-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	4273						80.00		
4	4274						75.56		do
	4275	22-03-2021	29-03-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	4276						75.56		
5	4277						75.56		do
	4278	23-03-2021	30-03-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	4279						80.00		
6	5606						80.00		No. WRD/SD I/WD II/ F.Estt/37/2021-22. DATED: 16-04-2021
	5607	10/4/2021	17-04-2021	Foundation	1.3.6	70 kg/cm2	71.11	75.56	
	5608						75.56		
7	5609						75.56		do
	5610	11/4/2021	18-04-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	5611						75.56		
8	5612						75.56		do
	5613	12/4/2021	19-04-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	5614						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9	5615						75.56		No. WRD/SD I/WD II/ F.Estt/37/2021-22. DATED: 16-04-2021
	5616	13-04-2021	20-04-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	5617						75.56		
10	5618						75.56		do
	5619	14-04-2021	21-04-2021	Foundation	1.3.6	70 kg/cm2	66.65	74.07	
	5620						80.00		
11	5621						75.56		do
	5622	15-04-2021	22-04-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	5623						80.00		
12	6296						75.56		No. WRD/SD I/WD II/ F.Estt/62/2021-22. DATED: 23-04-2021
	6297	17-04-2021	24-04-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	6298						75.56		
13	6299						75.56		do
	6300	19-04-2021	26-04-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	6301						80.00		
14	6302						80.00		do
	6303	20-04-2021	27-04-2021	Foundation	1.3.6	70 kg/cm2	71.11	75.56	
	6304						75.56		
15	6305						75.56		do
	6306	21-04-2021	28-04-2021	Foundation	1.3.6	70 kg/cm2	80.00	77.04	
	6307						75.56		
16	6308						75.56		do
	6309	22-04-2021	29-04-2021	Foundation	1.3.6	70 kg/cm2	84.44	80.00	
	6310						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Protective measures to the bund in Sy. No. 32 & 33 at Xetmalem in V.P. Carmona of Salcete Taluka. (2nd Call).

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17	6686						66.65		No. WRD/SD I/WD II/ F.Estt/83/2021-22. DATED: 03-05-2021
	6687	26-04-2021	3/5/2021	Foundation	1.3.6	70 kg/cm2	75.56	74.07	
	6688						80.00		
18	6689						75.56		
	6690	27-04-2021	4/5/2021	Foundation	1.3.6	70 kg/cm2	66.65	72.59	do
	6691						75.56		
19	6692						75.56		
	6693	28-04-2021	5/5/2021	Foundation	1.3.6	70 kg/cm2	66.65	72.59	do
	6694						75.56		
20	6695						71.11		
	6696	29-04-2021	6/5/2021	Foundation	1.3.6	70 kg/cm2	80.00	75.56	do
	6697						75.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER