

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Desilting of nallah and Construction of retaining wall in Sy.No. 15/2 of ward No.1 at Cumborda in Village Panchayat Verna in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	542						115.56		No. WRD/SD I/ WD II/ F.Esst/406/2021-22 DATED:- 13-12-2021.
	543	6/12/2021	13-12-2021	Foundation	1.2.4	100 kg/cm ²	120.00	118.52	
	544						120.00		
2	545						115.56		do
	546	8/12/2021	15-12-2021	Foundation	1.2.4	100 kg/cm ²	120.00	115.56	
	547						111.11		
3	548						115.56		do
	549	10/12/2021	17-12-2021	Foundation	1.2.4	100 kg/cm ²	124.44	117.04	
	550						111.11		
4	551						120.00		do
	552	11/12/2021	18-12-2021	Foundation	1.2.4	100 kg/cm ²	115.56	118.52	
	553						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER