

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to the nallah bank at Mapa Panchwadi in Sy.No. 257/5, 6, 7 in V.P. Panchwadi Shiroda Constituency (2 nd call).

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	6944						115.56		No. WRD/WD XI/ SD IV/ F.cf/66/2021-22. <b>DATED: 11-05-2021.</b>
	6945	5/5/2021	12/5/2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	6946						120.00		
1.2	6947						115.56		do
	6948	5/5/2021	12/5/2021	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	6949						111.11		
2.1	6950						115.56		do
	6951	6/5/2021	13-05-2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	6952						111.11		
2.2	6953						120.00		do
	6954	6/5/2021	13-05-2021	Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	6955						111.11		
3.1	6956						115.56		do
	6957	7/5/2021	14-05-2021	Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	6958						120.00		
3.2	6959						115.56		do
	6960	7/5/2021	14-05-2021	Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	6961						115.56		
4.1	6962						111.11		do
	6963	8/5/2021	15-05-2021	Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	6964						120.00		
4.2	6965						115.56		do
	6966	8/5/2021	15-05-2021	Foundation	1.2.4	100 kg/cm2	115.56	117.04	
	6967						120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to the nallah bank at Mapa Panchwadi in Sy.No. 257/5, 6, 7 in V.P. Panchwadi Shiroda Constituency (2 nd call).

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	6968						106.67		No. WRD/WD XI/ SD IV/
	6969	10/5/2021	17-05-2021	Foundation	1.2.4	100 kg/cm2	97.78	105.19	F.cf/66/2021-22.
	6970						111.11		<b>DATED: 11-05-2021.</b>
5.2	6971						106.67		
	6972	10/5/2021	17-05-2021	Foundation	1.2.4	100 kg/cm2	106.67	108.15	do
	6973						111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**