

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of 45 Nos. RCC open shallow wells at various locations in Nuvem Constituency Salcete Taluka Goa.

**SAMPLE SENT BY:** AE, SD III, WD III, WRD, Gogol- Margao - Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	7700						160.00		No. 270/T/SD III/ WD III/WRD/2021-22/82 <b>DATED: 08-06-2021</b>
	7701	2/6/2021	9/6/2021	Well rings	1.1.5.3	135 kg/cm <sup>2</sup>	151.11	154.07	
	7702						151.11		
2	7703						160.00		
	7704	3/6/2021	10/6/2021	Well rings	1.1.5.3	135 kg/cm <sup>2</sup>	160.00	157.04	do
	7705						151.11		
3	7706						155.56		
	7707	4/6/2021	11/6/2021	Well rings	1.1.5.3	135 kg/cm <sup>2</sup>	155.56	155.56	do
	7708						155.56		
4	7709						160.00		
	7710	5/6/2021	12/6/2021	Well rings	1.1.5.3	135 kg/cm <sup>2</sup>	151.11	154.07	do
	7711						151.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**