

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Urgent repair to the existing irrigation tank & Improvement to canal at Gauthan Priol in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	2180						120.00		No. WRD/WD XI/SD IV/ F.CF/144/2020-21. DATED: 22-02-2021
	2181	16-02-2021	23-02-2021	for base	1.2.4	100 kg/cm2	124.44	121.48	
	2182						120.00		
2	2183						120.00		
	2184	17-02-2021	24-02-2021	for base	1.2.4	100 kg/cm2	120.00	120.00	do
	2185						120.00		
3	2186						111.11		
	2187	19-02-2021	26-02-2021	for base and wall	1.2.4	100 kg/cm2	115.56	114.08	do
	2188						115.56		
4	2189						111.11		
	2190	20-02-2021	27-02-2021	for base wall of canal	1.2.4	100 kg/cm2	115.56	113.34	do
	2191						115.56		