

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	6170						111.11		No. WRD/WD XII/ SD V/ F.15/09/2021-22. <b>DATED: 15-04-2021</b>
	6171	9/4/2021	16-04-2021	Foundation	1.2.4	100 kg/cm2	102.22	111.11	
	6172						120.00		
1.2	6173						111.11		do
	6174	9/4/2021	16-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	109.63	
	6175						106.67		
1.3	6176						111.11		do
	6177	9/4/2021	16-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	112.59	
	6178						115.56		
2.1	6179						97.78		do
	6180	10/4/2021	17-04-2021	Foundation	1.2.4	100 kg/cm2	115.56	111.11	
	6181						120.00		
2.2	6182						111.11		do
	6183	10/4/2021	17-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	112.59	
	6184						115.56		
2.3	6185						97.78		do
	6186	10/4/2021	17-04-2021	Foundation	1.2.4	100 kg/cm2	115.56	111.11	
	6187						120.00		
3.1	6188						111.11		do
	6189	11/4/2021	18-04-2021	Foundation	1.2.4	100 kg/cm2	102.22	111.11	
	6190						120.00		
3.2	6191						111.11		do
	6192	11/4/2021	18-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	109.63	
	6193						106.67		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and Development of flood water nallah passing through survey No. 28/1 - F of Village cacora Kadebag in Curchorem Constituency.

**SAMPLE SENT BY:** AE, SD V, WD XII, WRD, Quepem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
4.1	6194						111.11		No. WRD/WD XII/ SD V/ F.15/09/2021-22. <b>DATED: 15-04-2021</b>
	6195	12/4/2021	19-04-2021	1st Lift	1.2.4	100 kg/cm <sup>2</sup>	111.11	109.63	
	6196						106.67		
4.2	6197						111.11		do
	6198	12/4/2021	19-04-2021	1st Lift	1.2.4	100 kg/cm <sup>2</sup>	111.11	112.59	
	6199						115.56		
5.1	6200						97.78		do
	6201	14-04-2021	21-04-2021	1st Lift	1.2.4	100 kg/cm <sup>2</sup>	115.56	111.11	
	6202						120.00		
5.2	6203						111.11		do
	6204	14-04-2021	21-04-2021	1st Lift	1.2.4	100 kg/cm <sup>2</sup>	111.11	112.59	
	6205						115.56		
5.3	6206						97.78		do
	6207	14-04-2021	21-04-2021	1st Lift	1.2.4	100 kg/cm <sup>2</sup>	115.56	111.11	
	6208						120.00		
6	6128						111.11		No. WRD/WD XII/ SD V/ F.15/14/2021-22. <b>DATED: 21-04-2021</b>
	6129	19-04-2021	26-04-2021	4th lift Middle band	1.2.4	100 kg/cm <sup>2</sup>	111.11	112.59	
	6130						115.56		
7	6131						111.11		do
	6132	20-04-2021	27-04-2021	5th Lift	1.2.4	100 kg/cm <sup>2</sup>	111.11	109.63	
	6133						106.67		

**Sandip Parab  
JUNIOR ENGINEER.**

**Pravin C Parsekar  
ASSISTANT ENGINEER**