

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Urgent protection to nallah bank at Codar in V.P. Betoda Nirankal Conxem Codar in Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	8465						106.67		No. WRD/WD XI/ SD IV/ F.cf/181/2021-22. <b>DATED: 12-07-2021</b>
	8466	5/7/2021	12/7/2021	Foundation	1.2.4	100 kg/cm <sup>2</sup>	106.67	108.15	
	8467						111.11		
2	8468						106.67		do
	8469	6/7/2021	13-07-2021	Foundation	1.2.4	100 kg/cm <sup>2</sup>	106.67	108.15	
	8470						111.11		
3	8471						111.11		do
	8472	8/7/2021	15-07-2021	Foundation	1.2.4	100 kg/cm <sup>2</sup>	111.11	111.11	
	8473						111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**