

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Strengthening of bund in Sy.No. 172 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7607						168.89		No. WRD/SD I/ WD II/
	7608	5/5/2021	2/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	F.Esst/108/2021-22
	7609						168.89		DATED:- 21-05-2021
1.2	7610						164.44		
	7611	5/5/2021	2/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	7612						168.89		
2.1	7613						164.44		
	7614	7/5/2021	4/6/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	7615						168.89		
2.2	7616						164.44		
	7617	7/5/2021	4/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	7618						168.89		
3.1	7619						168.89		
	7620	10/5/2021	7/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	7621						168.89		
3.2	7622						168.89		
	7623	10/5/2021	7/6/2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	7624						168.89		
4.1	7625						164.44		
	7626	12/5/2021	9/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	7627						168.89		
4.2	7628						168.89		
	7629	12/5/2021	9/6/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	7630						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and Strengthening of bund in Sy.No. 172 in Village Chinchinim in Velim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	7631						160.00		No. WRD/SD I/ WD II/
	7632	15-05-2021	12/6/2021	Coping	1.2.4	150 kg/cm2	164.44	161.48	F.Esst/108/2021-22
	7633						160.00		DATED:- 21-05-2021
5.2	7634						164.44		
	7635	15-05-2021	12/6/2021	Coping	1.2.4	150 kg/cm2	155.56	160.00	do
	7636						160.00		
6	7637						164.44		
	7638	17-05-2021	14-06-2021	Coping	1.2.4	150 kg/cm2	164.44	165.92	do
	7639						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER