

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of Pond, Sluice gate and outlet in Sy.No. 85 in Village Deussua Velim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7410						186.67		No. WRD/SD I/WD II/ F.Estt/92/2021-22. <b>DATED: 03-05-2021.</b>
	7411	5/4/2021	3/5/2021	Foundation	1.2.4	150 kg/cm2	186.67	185.19	
	7412						182.22		
1.2	7413						191.11		do
	7414	5/4/2021	3/5/2021	Foundation	1.2.4	150 kg/cm2	186.67	188.15	
	7415						186.67		
2.1	7416						186.67		do
	7417	7/4/2021	5/5/2021	Foundation	1.2.4	150 kg/cm2	186.67	186.67	
	7418						186.67		
2.2	7419						191.11		do
	7420	7/4/2021	5/5/2021	Foundation	1.2.4	150 kg/cm2	186.67	188.15	
	7421						186.67		
3.1	7422						182.22		do
	7423	9/4/2021	7/5/2021	Wall	1.2.4	150 kg/cm2	177.78	177.78	
	7424						173.33		
3.2	7425						182.22		do
	7426	9/4/2021	7/5/2021	Wall	1.2.4	150 kg/cm2	182.22	183.70	
	7427						186.67		
4.1	7428						177.78		do
	7429	12/4/2021	10/5/2021	Wall	1.2.4	150 kg/cm2	177.78	179.26	
	7430						182.22		
4.2	7431						186.67		do
	7432	12/4/2021	10/5/2021	Wall	1.2.4	150 kg/cm2	186.67	183.71	
	7433						177.78		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of Pond, Sluice gate and outlet in Sy.No. 85 in Village Deussua Velim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	7434						186.67		No. WRD/SD I/WD II/ F.Estt/92/2021-22. <b>DATED: 03-05-2021.</b>
	7435	15-04-2021	13-05-2021	Foundation	1.2.4	150 kg/cm2	186.67	186.67	
	7436						186.67		
5.2	7437						191.11		do
	7438	15-04-2021	13-05-2021	Foundation	1.2.4	150 kg/cm2	186.67	188.15	
	7439						186.67		
6.1	7440						186.67		do
	7441	17-04-2021	15-05-2021	Foundation & Wall	1.2.4	150 kg/cm2	186.67	185.19	
	7442						182.22		
6.2	7443						191.11		do
	7444	17-04-2021	15-05-2021	Foundation & Wall	1.2.4	150 kg/cm2	186.67	188.15	
	7445						186.67		
7.1	7446						186.67		do
	7447	19-04-2021	17-05-2021	Wall	1.2.4	150 kg/cm2	186.67	186.67	
	7448						186.67		
7.2	7449						191.11		do
	7450	19-04-2021	17-05-2021	Wall	1.2.4	150 kg/cm2	186.67	188.15	
	7451						186.67		
8.1	7452						182.22		do
	7453	21-04-2021	19-05-2021	Wall	1.2.4	150 kg/cm2	177.78	177.78	
	7454						173.33		
8.2	7455						182.22		do
	7456	21-04-2021	19-05-2021	Wall	1.2.4	150 kg/cm2	182.22	183.70	
	7457						186.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**