

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of Gonsua lake in Sy.No. 14/12 at Village Gonsua in V.P. Betalbatim in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | | |
|--------------------|-------------|--------------|--------------|--------------------|---------------|-------------------|--------------------|------------------|--|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
| 1.1 | 7946 | | | | | | 168.89 | | No. SD I/ WD II/ WRD/ F.Estt/149/2020-21. DATED: 09-06-2021 |
| | 7947 | 15-05-2021 | 12/6/2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 167.41 | |
| | 7948 | | | | | | 168.89 | | |
| 1.2 | 7949 | | | | | | 168.89 | | |
| | 7950 | 15-05-2021 | 12/6/2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | do |
| | 7951 | | | | | | 168.89 | | |
| 1.3 | 7952 | | | | | | 173.33 | | |
| | 7953 | 15-05-2021 | 12/6/2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | do |
| | 7954 | | | | | | 164.44 | | |
| 1.4 | 7955 | | | | | | 173.33 | | |
| | 7956 | 15-05-2021 | 12/6/2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 170.37 | do |
| | 7957 | | | | | | 168.89 | | |
| 2.1 | 7958 | | | | | | 160.00 | | |
| | 7959 | 16-05-2021 | 13-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 162.96 | do |
| | 7960 | | | | | | 164.44 | | |
| 2.2 | 7961 | | | | | | 164.44 | | |
| | 7962 | 16-05-2021 | 13-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 164.44 | do |
| | 7963 | | | | | | 164.44 | | |
| 2.3 | 7964 | | | | | | 164.44 | | |
| | 7965 | 16-05-2021 | 13-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 165.92 | do |
| | 7966 | | | | | | 168.89 | | |
| 2.4 | 7967 | | | | | | 164.44 | | |
| | 7968 | 16-05-2021 | 13-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 160.00 | 162.96 | do |
| | 7969 | | | | | | 164.44 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of Gonsua lake in Sy.No. 14/12 at Village Gonsua in V.P. Betalbatim in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|-------------|--------------|--------------|--------------------|---------------|-------------------|--------------------|------------------|--|
| 3.1 | 7970 | | | | | | 168.89 | | No. SD I/ WD II/ WRD/ F.Estt/149/2020-21. DATED: 09-06-2021 |
| | 7971 | 18-05-2021 | 15-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 167.41 | |
| | 7972 | | | | | | 168.89 | | |
| 3.2 | 7973 | | | | | | 164.44 | | do |
| | 7974 | 18-05-2021 | 15-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 165.92 | |
| | 7975 | | | | | | 168.89 | | |
| 3.3 | 7976 | | | | | | 164.44 | | do |
| | 7977 | 18-05-2021 | 15-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 167.41 | |
| | 7978 | | | | | | 168.89 | | |
| 3.4 | 7979 | | | | | | 164.44 | | do |
| | 7980 | 18-05-2021 | 15-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 165.92 | |
| | 7981 | | | | | | 168.89 | | |
| 4.1 | 7982 | | | | | | 168.89 | | do |
| | 7983 | 20-05-2021 | 17-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 167.41 | |
| | 7984 | | | | | | 168.89 | | |
| 4.2 | 7985 | | | | | | 168.89 | | do |
| | 7986 | 20-05-2021 | 17-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | |
| | 7987 | | | | | | 168.89 | | |
| 4.3 | 7988 | | | | | | 164.44 | | do |
| | 7989 | 20-05-2021 | 17-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 165.92 | |
| | 7990 | | | | | | 168.89 | | |
| 4.4 | 7991 | | | | | | 168.89 | | do |
| | 7992 | 20-05-2021 | 17-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 167.41 | |
| | 7993 | | | | | | 164.44 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of Gonsua lake in Sy.No. 14/12 at Village Gonsua in V.P. Betalbatim in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|-------------|--------------|--------------|--------------------|---------------|-------------------|--------------------|------------------|--|
| 5.1 | 7994 | | | | | | 168.89 | | No. SD I/ WD II/ WRD/ F.Estt/149/2020-21. DATED: 09-06-2021 |
| | 7995 | 22-05-2021 | 19-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 165.93 | |
| | 7996 | | | | | | 160.00 | | |
| 5.2 | 7997 | | | | | | 164.44 | | do |
| | 7998 | 22-05-2021 | 19-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 164.44 | |
| | 7999 | | | | | | 164.44 | | |
| 5.3 | 8000 | | | | | | 164.44 | | do |
| | 8001 | 22-05-2021 | 19-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 164.44 | |
| | 8002 | | | | | | 164.44 | | |
| 5.4 | 8003 | | | | | | 164.44 | | do |
| | 8004 | 22-05-2021 | 19-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 168.89 | 165.92 | |
| | 8005 | | | | | | 164.44 | | |
| 6.1 | 8006 | | | | | | 160.00 | | do |
| | 8007 | 23-05-2021 | 20-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 162.96 | |
| | 8008 | | | | | | 164.44 | | |
| 6.2 | 8009 | | | | | | 164.44 | | do |
| | 8010 | 23-05-2021 | 20-06-2021 | Foundation | 1.2.4 | 150 kg/cm2 | 164.44 | 164.44 | |
| | 8011 | | | | | | 164.44 | | |
| 7.1 | 8012 | | | | | | 164.44 | | do |
| | 8013 | 25-05-2021 | 22-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 168.89 | 165.92 | |
| | 8014 | | | | | | 164.44 | | |
| 7.2 | 8015 | | | | | | 168.89 | | do |
| | 8016 | 25-05-2021 | 22-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 164.44 | 167.41 | |
| | 8017 | | | | | | 168.89 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Development of Gonsua lake in Sy.No. 14/12 at Village Gonsua in V.P. Betalbatim in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|-------------|--------------|--------------|--------------------|---------------|-------------------|--------------------|------------------|--|
| 7.3 | 8018 | | | | | | 168.89 | | No. SD I/ WD II/ WRD/ F.Estt/149/2020-21. DATED: 09-06-2021 |
| | 8019 | 25-05-2021 | 22-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 164.44 | 167.41 | |
| | 8020 | | | | | | 168.89 | | |
| 7.4 | 8021 | | | | | | 168.89 | | do |
| | 8022 | 25-05-2021 | 22-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | |
| | 8023 | | | | | | 168.89 | | |
| 7.5 | 8024 | | | | | | 173.33 | | do |
| | 8025 | 25-05-2021 | 22-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | |
| | 8026 | | | | | | 164.44 | | |
| 8.1 | 8027 | | | | | | 173.33 | | do |
| | 8028 | 27-05-2021 | 24-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 168.89 | 170.37 | |
| | 8029 | | | | | | 168.89 | | |
| 8.2 | 8030 | | | | | | 160.00 | | do |
| | 8031 | 27-05-2021 | 24-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 164.44 | 162.96 | |
| | 8032 | | | | | | 164.44 | | |
| 8.3 | 8033 | | | | | | 164.44 | | do |
| | 8034 | 27-05-2021 | 24-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 164.44 | 164.44 | |
| | 8035 | | | | | | 164.44 | | |
| 8.4 | 8036 | | | | | | 164.44 | | do |
| | 8037 | 27-05-2021 | 24-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 164.44 | 165.92 | |
| | 8038 | | | | | | 168.89 | | |
| 8.5 | 8039 | | | | | | 164.44 | | do |
| | 8040 | 27-05-2021 | 24-06-2021 | Wall | 1.2.4 | 150 kg/cm2 | 160.00 | 162.96 | |
| | 8041 | | | | | | 164.44 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER