

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the nallah side bank in Sy.No. 59/1 in Village Nagoa in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7626						177.78		No. WRD/SD I/WD II/ F.Estt/109/2021-22. DATED: 24-05-2021.
	7627	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	7628						173.33		
1.2	7629						173.33		do
	7630	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	173.33	173.33	
	7631						173.33		
2.1	7632						168.89		do
	7633	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	173.33	171.85	
	7634						173.33		
2.2	7635						168.89		do
	7636	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	170.37	
	7637						173.33		
2.3	7638						173.33		do
	7639	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	7640						177.78		
3.1	7641						177.78		do
	7642	18-05-2021	15-06-2021	Foundation	1.2.4	150 kg/cm2	177.78	177.78	
	7643						177.78		
3.2	7644						173.33		do
	7645	18-05-2021	15-06-2021	Foundation	1.2.4	150 kg/cm2	173.33	174.81	
	7646						177.78		
3.3	7647						177.78		do
	7648	18-05-2021	15-06-2021	Foundation	1.2.4	150 kg/cm2	177.78	176.30	
	7649						173.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of protection wall to the nallah side bank in Sy.No. 59/1 in Village Nagoa in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
4.1	7650						177.78		No. WRD/SD I/WD II/ F.Estt/109/2021-22. DATED: 24-05-2021.
	7651	20-05-2021	17-06-2021	Wall	1.2.4	150 kg/cm ²	182.22	179.26	
	7652						177.78		
4.2	7653						182.22		do
	7654	20-05-2021	17-06-2021	Wall	1.2.4	150 kg/cm ²	182.22	180.74	
	7655						177.78		
5.1	7656						177.78		do
	7657	21-05-2021	18-06-2021	Wall	1.2.4	150 kg/cm ²	182.22	179.26	
	7658						177.78		
5.2	7659						182.22		do
	7660	21-05-2021	18-06-2021	Wall	1.2.4	150 kg/cm ²	182.22	180.74	
	7661						177.78		
6.1	7662						177.78		do
	7663	22-05-2021	19-06-2021	Wall	1.2.4	150 kg/cm ²	177.78	179.26	
	7664						182.22		
6.2	7665						177.78		do
	7666	22-05-2021	19-06-2021	Wall	1.2.4	150 kg/cm ²	177.78	177.78	
	7667						177.78		
6.3	7668						177.78		do
	7669	22-05-2021	19-06-2021	Wall	1.2.4	150 kg/cm ²	173.33	176.30	
	7670						177.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER