

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7829						168.89		No. WRD/SD I/ WD II/
	7830	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	F.Esst/137/2021-22
	7831						168.89		<b>DATED:- 07-06-2021</b>
1.2	7832						164.44		
	7833	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	7834						168.89		
1.3	7835						164.44		
	7836	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	7837						168.89		
2.1	7838						168.89		
	7839	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	7840						168.89		
2.2	7841						168.89		
	7842	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	7843						168.89		
2.3	7844						168.89		
	7845	17-05-2021	14-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	7846						168.89		
3.1	7847						168.89		
	7848	19-05-2021	16-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	7849						168.89		
3.2	7850						168.89		
	7851	19-05-2021	16-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	7852						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	7853						168.89		No. WRD/SD I/ WD II/
	7854	19-05-2021	16-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	F.Esst/137/2021-22
	7855						168.89		<b>DATED:- 07-06-2021</b>
4.1	7856						164.44		
	7857	20-05-2021	17-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	7858						168.89		
4.2	7859						164.44		
	7860	20-05-2021	17-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	7861						168.89		
4.3	7862						164.44		
	7863	20-05-2021	17-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	7864						168.89		
5.1	7865						168.89		
	7866	21-05-2021	18-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	7867						168.89		
5.2	7868						168.89		
	7869	21-05-2021	18-06-2021	Foundation	1.2.4	150 kg/cm2	168.89	168.89	do
	7870						168.89		
5.3	7871						164.44		
	7872	21-05-2021	18-06-2021	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	7873						168.89		
6.1	7874						168.89		
	7875	22-05-2021	19-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	7876						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	7877						168.89		No. WRD/SD I/ WD II/ F.Esst/137/2021-22 <b>DATED:- 07-06-2021</b>
	7878	22-05-2021	19-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	164.44	167.41	
	7879						168.89		
6.3	7880						168.89		do
	7881	22-05-2021	19-06-2021	Foundation & Wall	1.2.4	150 kg/cm2	168.89	168.89	
	7882						168.89		
7.1	7883						173.33		do
	7884	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	
	7885						164.44		
7.2	7886						173.33		do
	7887	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	168.89	170.37	
	7888						168.89		
7.3	7889						160.00		do
	7890	24-05-2021	21-06-2021	Walls	1.2.4	150 kg/cm2	164.44	162.96	
	7891						164.44		
8.1	7892						164.44		do
	7893	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7894						164.44		
8.2	7895						164.44		do
	7896	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	164.44	165.92	
	7897						168.89		
8.3	7898						164.44		do
	7899	25-05-2021	22-06-2021	Walls	1.2.4	150 kg/cm2	160.00	162.96	
	7900						164.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	7901						168.89		No. WRD/SD I/ WD II/ F.Esst/137/2021-22 <b>DATED:- 07-06-2021</b>
	7902	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm2	168.89	165.93	
	7903						160.00		
9.2	7904						164.44		do
	7905	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7906						164.44		
9.3	7907						164.44		do
	7908	26-05-2021	23-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7909						164.44		
10.1	7910						164.44		do
	7911	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm2	168.89	165.92	
	7912						164.44		
10.2	7913						160.00		do
	7914	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm2	164.44	162.96	
	7915						164.44		
10.3	7916						164.44		do
	7917	27-05-2021	24-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	
	7918						164.44		
11.1	7919						164.44		do
	7920	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm2	168.89	165.92	
	7921						164.44		
11.2	7922						168.89		do
	7923	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm2	164.44	167.41	
	7924						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of pond in Sy.No. 1/41 and Improvement of outlet in Village Sirlim of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
11.3	7925						168.89		No. WRD/SD I/ WD II/
	7926	28-05-2021	25-06-2021	Walls	1.2.4	150 kg/cm2	164.44	167.41	F.Esst/137/2021-22
	7927						168.89		<b>DATED:- 07-06-2021</b>
12.1	7928						168.89		
	7929	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	do
	7930						168.89		
12.2	7931						173.33		
	7932	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	168.89	do
	7933						164.44		
12.3	7934						173.33		
	7935	29-05-2021	26-06-2021	Walls	1.2.4	150 kg/cm2	168.89	170.37	do
	7936						168.89		
13.1	7937						160.00		
	7938	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	162.96	do
	7939						164.44		
13.2	7940						164.44		
	7941	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	164.44	do
	7942						164.44		
13.3	7943						164.44		
	7944	30-05-2021	27-06-2021	Walls	1.2.4	150 kg/cm2	164.44	165.92	do
	7945						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**