

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to drain at Soshebhat in V.P. Durbhat in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	8648						115.56		No. WRD/WD XI/ SD IV/ W.F.483/195/2021-22. DATED: 20-07-2021
	8649	13-07-2021	20-07-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	8650						120.00		
1.2	8651						115.56		do
	8652	13-07-2021	20-07-2021	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	8653						111.11		
2.1	8654						115.56		do
	8655	14-07-2021	21-07-2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	8656						111.11		
2.2	8657						120.00		do
	8658	14-07-2021	21-07-2021	Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	8659						111.11		
3.1	8660						115.56		do
	8661	15-07-2021	22-07-2021	Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	8662						120.00		
3.2	8663						115.56		do
	8664	15-07-2021	22-07-2021	Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	8665						115.56		
4.1	8666						111.11		do
	8667	16-07-2021	23-07-2021	Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	8668						120.00		
4.2	8669						115.56		do
	8670	16-07-2021	23-07-2021	Foundation	1.2.4	100 kg/cm2	115.56	117.04	
	8671						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER