

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7350						186.67		No. WRD/SD I/WD II/ F.Estt/104/2021-22. DATED: 19-05-2021.
	7351	13-05-2021	10/6/2021	Foundation	1.2.4	150 kg/cm2	177.78	180.74	
	7352						177.78		
1.2	7353						186.67		do
	7354	13-05-2021	10/6/2021	Foundation	1.2.4	150 kg/cm2	186.67	183.71	
	7355						177.78		
2.1	7356						182.22		do
	7357	14-05-2021	11/6/2021	Foundation	1.2.4	150 kg/cm2	186.67	182.22	
	7358						177.78		
2.2	7359						186.67		do
	7360	14-05-2021	11/6/2021	Foundation	1.2.4	150 kg/cm2	182.22	183.70	
	7361						182.22		
3.1	7362						186.67		do
	7363	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	182.22	182.22	
	7364						177.78		
3.2	7365						182.22		do
	7366	15-05-2021	12/6/2021	Foundation	1.2.4	150 kg/cm2	182.22	183.70	
	7367						186.67		
4.1	7575						186.67		No. WRD/SD I/WD II/ F.Estt/111/2021-22. DATED: 24-05-2021.
	7576	17-05-2021	14-06-2021	Wall	1.2.4	150 kg/cm2	186.67	183.71	
	7577						177.78		
4.2	7578						186.67		do
	7579	17-05-2021	14-06-2021	Wall	1.2.4	150 kg/cm2	182.22	185.19	
	7580						186.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.3	7581						182.22		No. WRD/SD I/WD II/ F.Estt/111/2021-22. DATED: 24-05-2021.
	7582	17-05-2021	14-06-2021	Wall	1.2.4	150 kg/cm2	182.22	183.70	
	7583						186.67		
5.1	7584						186.67		do
	7585	18-05-2021	15-06-2021	Wall	1.2.4	150 kg/cm2	186.67	186.67	
	7586						186.67		
5.2	7587						186.67		do
	7588	18-05-2021	15-06-2021	Wall	1.2.4	150 kg/cm2	186.67	185.19	
	7589						182.22		
6.1	7590						186.67		do
	7591	19-05-2021	16-06-2021	Wall	1.2.4	150 kg/cm2	186.67	186.67	
	7592						186.67		
6.2	7593						182.22		do
	7594	19-05-2021	16-06-2021	Wall	1.2.4	150 kg/cm2	186.67	185.19	
	7595						186.67		
6.3	7596						186.67		do
	7597	19-05-2021	16-06-2021	Wall	1.2.4	150 kg/cm2	186.67	185.19	
	7598						182.22		
7.1	7599						186.67		do
	7600	20-05-2021	17-06-2021	Wall	1.2.4	150 kg/cm2	186.67	186.67	
	7601						186.67		
7.2	7602						182.22		do
	7603	20-05-2021	17-06-2021	Wall	1.2.4	150 kg/cm2	186.67	185.19	
	7604						186.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
7.3	7605						186.67		No. WRD/SD I/WD II/
	7606	20-05-2021	17-06-2021	Wall	1.2.4	150 kg/cm ²	186.67	186.67	F.Estt/111/2021-22.
	7607						186.67		DATED: 24-05-2021.

JUNIOR ENGINEER.

ASSISTANT ENGINEER