

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	7332						124.44		No. WRD/SD I/WD II/ F.Estt/104/2021-22. <b>DATED: 19-05-2021.</b>
	7333	13-05-2021	20-05-2021	Foundation	1.2.4	100 kg/cm2	111.11	117.04	
	7334						115.56		
1.2	7335						120.00		do
	7336	13-05-2021	20-05-2021	Foundation	1.2.4	100 kg/cm2	115.56	117.04	
	7337						115.56		
2.1	7338						115.56		do
	7339	14-05-2021	21-05-2021	Foundation	1.2.4	100 kg/cm2	97.78	109.63	
	7340						115.56		
2.2	7341						102.22		do
	7342	14-05-2021	21-05-2021	Foundation	1.2.4	100 kg/cm2	97.78	103.70	
	7343						111.11		
3.1	7344						111.11		do
	7345	15-05-2021	22-05-2021	Foundation	1.2.4	100 kg/cm2	111.11	112.59	
	7346						115.56		
3.2	7347						115.56		do
	7348	15-05-2021	22-05-2021	Foundation	1.2.4	100 kg/cm2	115.56	117.04	
	7349						120.00		
4.1	7542						115.56		No. WRD/SD I/WD II/ F.Estt/111/2021-22. <b>DATED: 24-05-2021.</b>
	7543	17-05-2021	24-05-2021	Wall	1.2.4	100 kg/cm2	115.56	115.56	
	7544						115.56		
4.2	7545						115.56		do
	7546	17-05-2021	24-05-2021	Wall	1.2.4	100 kg/cm2	111.11	114.08	
	7547						115.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.3	7548						120.00		No. WRD/SD I/WD II/ F.Estt/111/2021-22. <b>DATED: 24-05-2021.</b>
	7549	17-05-2021	24-05-2021	Wall	1.2.4	100 kg/cm2	120.00	118.52	
	7550						115.56		
5.1	7551						111.11		do
	7552	18-05-2021	25-05-2021	Wall	1.2.4	100 kg/cm2	106.67	111.11	
	7553						115.56		
5.2	7554						115.56		do
	7555	18-05-2021	25-05-2021	Wall	1.2.4	100 kg/cm2	97.78	109.63	
	7556						115.56		
6.1	7557						102.22		do
	7558	19-05-2021	26-05-2021	Wall	1.2.4	100 kg/cm2	97.78	103.70	
	7559						111.11		
6.2	7560						120.00		do
	7561	19-05-2021	26-05-2021	Wall	1.2.4	100 kg/cm2	115.56	115.56	
	7562						111.11		
6.3	7563						111.11		do
	7564	19-05-2021	26-05-2021	Wall	1.2.4	100 kg/cm2	115.56	115.56	
	7565						120.00		
7.1	7566						115.56		do
	7567	20-05-2021	27-05-2021	Wall	1.2.4	100 kg/cm2	97.78	109.63	
	7568						115.56		
7.2	7569						102.22		do
	7570	20-05-2021	27-05-2021	Wall	1.2.4	100 kg/cm2	97.78	103.70	
	7571						111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall on right side of Boxechem tollem at Dialgona in V.P. Telaulim in Navelim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
7.3	7572						97.78		No. WRD/SD I/WD II/
	7573	20-05-2021	27-05-2021	Wall	1.2.4	100 kg/cm <sup>2</sup>	115.56	105.19	F.Estt/111/2021-22.
	7574						102.22		<b>DATED: 24-05-2021.</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**