

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Bandhara Vetlegal in Sy.No. 84/2 and 77/1 in V.P. Bethora, Nirankal- Conxem. Codar of Shiroda Constituency in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	5834						111.11		No. WRD/WD XI/ SD IV/ F.408/16/2021-22. DATED: 15-04-2021.
	5835	10/4/2021	17-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	111.11	
	5836						102.22		
1.2	5837						102.22		
	5838	10/4/2021	17-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	114.07	do
	5839						120.00		
2.1	5840						111.11		
	5841	12/4/2021	19-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	111.11	do
	5842						102.22		
2.2	5843						102.22		
	5844	12/4/2021	19-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	114.07	do
	5845						120.00		
3.1	5846						97.78		
	5847	13-04-2021	20-04-2021	Foundation	1.2.4	100 kg/cm2	115.56	111.11	do
	5848						120.00		
3.2	5849						106.67		
	5850	13-04-2021	20-04-2021	Foundation	1.2.4	100 kg/cm2	106.67	111.11	do
	5851						120.00		
4.1	5852						120.00		
	5853	14-04-2021	21-04-2021	Foundation	1.2.4	100 kg/cm2	115.56	118.52	do
	5854						120.00		
4.2	5855						115.56		
	5856	14-04-2021	21-04-2021	Foundation	1.2.4	100 kg/cm2	115.56	117.04	do
	5857						120.00		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Bandhara Vetlegal in Sy.No. 84/2 and 77/1 in V.P. Bethora, Nirankal- Conxem. Codar of Shiroda Constituency in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	6488						115.56		No. WRD/WD XI/ SD IV/ F.408/39/2021-22. DATED: 29-04-2021.
	6489	22-04-2021	29-04-2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	6490						111.11		
5.2	6491						124.44		
	6492	22-04-2021	29-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	121.48	do
	6493						120.00		
6.1	6494						111.11		
	6495	23-04-2021	30-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	do
	6496						124.44		
6.2	6497						120.00		
	6498	23-04-2021	30-04-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	do
	6499						115.56		
7.1	6500						115.56		
	6501	24-04-2021	1/5/2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	do
	6502						111.11		
7.2	6503						124.44		
	6504	24-04-2021	1/5/2021	Foundation	1.2.4	100 kg/cm2	120.00	121.48	do
	6505						120.00		
8.1	6506						124.44		
	6507	27-04-2021	4/5/2021	Foundation	1.2.4	100 kg/cm2	120.00	120.00	do
	6508						115.56		
8.2	6509						120.00		
	6510	27-04-2021	4/5/2021	Foundation	1.2.4	100 kg/cm2	115.56	118.52	do
	6511						120.00		

Sandip Parab
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER