

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Drainage on existing waterway in Sy. No 121/2 at Chinchanagar Xeldem in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	320						213.33		No. WRD/WD XII/ SD V/ F.15/151/2020-21. DATED: 30-11-2020
	321	25-11-2020	22-12-2020	Foundation	1.2.4	210 kg/cm2	217.78	213.33	
	322						208.89		
1.2	323						208.89		
	324	25-11-2020	22-12-2020	Foundation	1.2.4	210 kg/cm2	213.33	210.37	do
	325						208.89		
2.1	326						213.33		
	327	26-11-2020	23-12-2020	1st Lift	1.2.4	210 kg/cm2	217.78	214.81	do
	328						213.33		
2.2	329						213.33		
	330	26-11-2020	23-12-2020	1st Lift	1.2.4	210 kg/cm2	217.78	213.33	do
	331						208.89		
3.1	332						217.78		
	333	27-11-2020	24-12-2020	2nd Lift	1.2.4	210 kg/cm2	208.89	211.85	do
	334						208.89		
3.2	335						213.33		
	336	27-11-2020	24-12-2020	2nd Lift	1.2.4	210 kg/cm2	217.78	214.81	do
	337						213.33		
4.1	338						213.33		
	339	28-11-2020	26-12-2020	3rd Lift	1.2.4	210 kg/cm2	217.78	213.33	do
	340						208.89		
4.2	341						208.89		
	342	28-11-2020	26-12-2020	3rd Lift	1.2.4	210 kg/cm2	217.78	214.82	do
	343						217.78		